

NB 2163

EU TYPE EXAMINATION CERTIFICATE

Certificate No: 2163-PPE-1795

Respiratory protective devices, filtering half masks to protect against particles manufactured by

PASHA HOME ITH. IHR. LTD. ŞTİ.

are tested and evaluated according to

**EN 149:2001 + A1:2009 Respiratory Protective Devices -Filtering
Half Masks to Protect Against Particles - Requirements,
Testing, Marking**

Based on the type examination conducted with the evaluation of test reports, technical file according to Personal Protective Equipment Regulation (EU) 2016/425 Annex 5, it is approved that the product meets the requirements of the regulation.

Product Definition

Single use particle filtering half mask for protection against solid and liquid aerosols, is a folding type, 5 layered, without valve, ear straps and adjustable nose bar.

Brand Name: Pasha Home

Model: PSH-NRFM001

Classification: FFP2 NR

Here by the manufacturer is allowed to use notified body number (2163) and can fix CE mark, as shown below, on the Category III product models given above, with;

-Issuing an appropriate EU Declaration of Conformity according to **Personal Protective Equipment Regulation (EU) 2016/425 Annex 9.**

-Ongoing successful performance in fulfilment of the requirements set out in Personal Protective **Equipment Regulation (EU) 2016/425** and harmonized standards, ensured by assessments based on **Annex 7 (Module C2) or Annex 8 (Module D)** of the regulation no later than 1 year from the beginning of serial production

This certificate is initially issued on **16/12/2020** and will be valid for 5 years, if there is no change in the relevant harmonized standard affecting the essential health and safety requirements.



Director

TECHNICAL ASSESSMENT REPORT

REPORT DATE / NO: 15.12.2020 / 2163-KKD-1795

Manufacturer: PASHA HOME ITH. IHR. LTD. ŞTİ.

Address: Mahmutbey Mah. Istoc 1. Ada No: 154-156 Bagcilar / Istanbul TURKEY

Introduction

This report is for the, given above, manufacturer prepared according to the test results obtained from ANHUI HONREN GROUP CO LTD, dated 13.12.2020 with Serial Id 12-2020-T0575 based on EN 149: 2001 + A1 : 2009 standard and the technical file dated 25 October 2020 (Revision 00) provided by the manufacturer.

The technical file of the manufacturer, and risk evaluation against the essential health safety requirements and the test report evaluated for their relation with Essential Requirements of Personal Protective Equipment Regulation and found to be appropriate.

This report is an annex and an integral part of the EU Type Examination Certificate issued to the manufacturer. The test results and issued certificate belongs only to the tested model. The technical report consists of a total of 6 pages.

Product Description: Single use particle filtering half mask for protection against solid and liquid aerosols, is a folding type, 5 layered, without valve, ear straps and adjustable nose bar.

Component and Materials:

Component	Material	Grade
Outer Layer	Spunbond fabric	50 g/m ²
Filter Layer I	Hot air cotton fabric	60 g/m
Filter Layer II	Melt-blown fabric	25 g/m
Inner Layer	Spunbond fabric	30 g/m
Ear Strap	Spandex + Nylon	Width 5+/- 1 mm Length: 200+20 mm
Nose Bridge	Polypropylene + Galvanized iron wire	Width 5+/-1 mm Diameter: 0,5 +/-0,02 mm

Classification: FFP2 NR

Brand name: Pasha Home **Model:** PSH-NRFM001



ESSENTIAL HEALTH and SAFETY REQUIREMENTS GIVEN IN EUROPEAN UNION REGULATION EU 2016/425 CORRESPONDING RISKS FOR THE PRODUCT

1.1. Design principles

1.1.1. Ergonomics

PPE must be so designed and manufactured that in the foreseeable conditions of use for which it is intended the user can perform the risk related activity normally whilst enjoying appropriate protection of the highest possible level.

1.1.2. Levels and classes of protection

1.1.2.1. Highest level of protection possible

The optimum level of protection to be taken into account in the design is that beyond which the constraints by the wearing of the PPE would prevent its effective use during the period of exposure to the risk or normal performance of the activity.

1.1.2.2. Classes of protection appropriate to different levels of risk

Where differing foreseeable conditions of use are such that several levels of the same risk can be distinguished, appropriate classes of protection must be taken into account in the design of the PPE.

1.2. Innocuousness of PPE

1.2.1. Absence of risks and other inherent nuisance factors

PPE must be so designed and manufactured as to preclude risks and other nuisance factors under foreseeable conditions of use.

1.2.1.1. Suitable constituent materials

The materials of which the PPE is made, including any of their possible decomposition products, must not adversely affect the health or safety of users.

1.2.1.2. Satisfactory surface condition of all PPE parts in contact with the user

Any part of the PPE that is in contact or is liable to come into contact with the user when the PPE is worn must be free of rough surfaces, sharp edges, sharp points and the like which could cause excessive irritation or injuries

1.2.1.3. Maximum permissible user impediment

Any impediment caused by PPE to movements to be made, postures to be adopted and sensory perception must be minimized; nor must PPE cause movements which endanger the user or other persons.

1.3. Comfort and effectiveness

1.3.1. Adaptation of PPE to user morphology

PPE must be designed and manufactured in such a way as to facilitate its correct positioning on the user and to remain in place for the foreseeable period of use, bearing in mind ambient factors, the actions to be carried out and the postures to be adopted. For this purpose, it must be possible to adapt the PPE to fit the morphology of the user by all appropriate means, such as adequate adjustment and attachment systems or the provision of an adequate range of sizes.

1.3.2. Lightness and design strength

PPE must be as light as possible without prejudicing design strength and efficiency.

Apart from the specific additional requirements which they must satisfy in order to provide adequate protection against the risks in question (see 3), PPE must be capable of withstanding the effects of ambient phenomena inherent under the foreseeable conditions of use

1.4. Information supplied by the manufacturer

The notes that must be drawn up by the former and supplied when PPE is placed on the market must contain all relevant information on:

- a) In addition to the name and address of the manufacturer and/or his authorized representative established in the Community
 - b) Storage, use, cleaning, maintenance, servicing and disinfection. cleaning, maintenance or disinfectant protection recommended by manufacturers must have no adverse effect on PPE or users when applied in accordance with the relevant instructions:
 - c) Performance as recorded during technical tests to check the levels or classes of protection provided by the PPE in question;
 - d) Suitable PPE accessories and the characteristics of appropriate spare parts;
 - e) The classes of protection appropriate to different levels of risk and the corresponding limits of use:
 - f) The obsolescence deadline or period of obsolescence of PPE or certain of its components:
 - g) The type of packaging suitable for transport:
 - h) The significance of any markings (see 2.12)
 - i) Where appropriate the references of the Directives applied in accordance with Article 5(6) (b);
 - j) The name, address and identification number of the notified body involved in the design stage of the PPE
- These notes, which must be precise and comprehensible, must be provided at least in the official language(s) of the member state of destination



2. ADDITIONAL REQUIREMENTS COMMON TO SEVERAL CLASSES OR TYPES OF PPE

2.1. PPE incorporating adjustment systems

If PPE incorporates adjustment systems, the latter must be designed and manufactured so that, after adjustment, they do not become undone unintentionally in the foreseeable conditions of use.

2.3. PPE for the face, eyes and respiratory system

Any restriction of the user's face, eyes, field of vision or respiratory system by the PPE shall be minimized.

The screens for those types of PPE must have a degree of optical neutrality that is compatible with the degree of precision and the duration of the activities of the user.

If necessary, such PPE must be treated or provided with means to prevent misting-up.

Models of PPE intended for users requiring sight correction must be compatible with the wearing of spectacles or contact lenses.

2.4. PPE subject to ageing

If it is known that the design performance of new PPE may be significantly affected by ageing, the month and year of manufacture and/or, if possible, the month and year of obsolescence must be indelibly and unambiguously marked on each item of PPE placed on the market and on its packaging.

If the manufacturer is unable to give an undertaking with regard to the useful life of the PPE, his instructions must provide all the information necessary to enable the purchaser or user to establish a reasonable obsolescence month and year, taking into account the quality level of the model and the effective conditions of storage, use, cleaning, servicing and maintenance.

Where appreciable and rapid deterioration in PPE performance is likely to be caused by ageing resulting from the periodic use of a cleaning process recommended by the manufacturer, the latter must if possible, affix a marking to each item of PPE placed on the market indicating the maximum number of cleaning operations that may be carried out before the equipment needs to be inspected or discarded. Where such a marking is not affixed, the manufacturer must give that information in his instructions.

2.6. PPE for use in potentially explosive atmospheres

PPE intended for use in potentially explosive atmospheres must be designed and manufactured in such a way that it cannot be the source of an electric, electrostatic or impact-induced arc or spark likely to cause an explosive mixture to ignite.

2.8. PPE for intervention in very dangerous situations

The instructions supplied by the manufacturer with PPE for intervention in very dangerous situations must include, in particular, data intended for competent, trained persons who are qualified to interpret them and ensure their application by the user.

The instructions must also describe the procedure to be adopted in order to verify that PPE is correctly adjusted and functional when worn by the user. Where PPE incorporates an alarm which is activated in the absence of the level of protection normally provided, the alarm must be designed and placed so that it can be perceived by the user in the foreseeable conditions of use.

2.9. PPE incorporating components which can be adjusted or removed by the user

Where PPE incorporates components which can be attached, adjusted or removed by the user for replacement purposes, such components must be designed and manufactured so that they can be easily attached, adjusted and removed without tools.

2.12. PPE bearing one or more identification or recognition marks directly or indirectly relating to health and safety

The identification or recognition marks directly or indirectly relating to health and safety affixed to these types or classes of must preferably take the form of harmonized pictograms or ideograms and must remain perfectly legible throughout the foreseeable useful life of the PPE. In addition, these marks must be complete, precise and comprehensible so as to prevent any misinterpretation: in particular, where such marks incorporate words or sentences, the latter must appear in the official language(s) of the Member State where the equipment is to be used.

If PPE (or a PPE component) is too small to allow all for part of the necessary marking to be affixed, the relevant information must be mentioned on the packing and in the manufacturer's notes.

3. ADDITIONAL REQUIREMENTS SPECIFIC TO PARTICULAR RISKS

3.10.1. Respiratory protection

PPE intended for the protection of the respiratory system must make it possible to supply the user with breathable air when exposed to a polluted atmosphere and/or an atmosphere having an inadequate oxygen concentration.

The breathable air supplied to the user by PPE must be obtained by appropriate means, for example after filtration of the polluted air through PPE or by supply from an external unpolluted source.

The constituent materials and other components of those types of PPE must be chosen or designed and incorporated so as to ensure appropriate user respiration and respiratory hygiene for the period of wear concerned under the foreseeable conditions of use.

The leak-tightness of the facepiece and the pressure drop on inspiration and in the case of the filtering devices, purification capacity must keep contaminant penetration from a polluted atmosphere low enough not to be prejudicial to the health or hygiene of the user.

The PPE must bear details of the specific characteristics of the equipment which, in conjunction with the instructions, enable a trained and qualified user to employ the PPE correctly.

In the case of filtering equipment, the manufacturer's instructions must also indicate the time limit for the storage of new original packaging.



Technical Assessment of EN 149: 2001 + A1: 2009 Standard and other Standards it refers to, Clauses Corresponding to the (EU) 2016/425 Directive

Conforming to EN 149:2001 + A1:2009 Standard Requirements				
Article 5	<p>Classification: Particle Filtering Half Mask</p> <p>The mask subject to evaluation based on the test results and technical file provided by the manufacturer is classified as: Filtering Efficiency and Maximum Total Inward Leakage- Classified as FFP2</p> <p>Mask is classified for single shift use NR</p>			
Article 7.4	<p>Packaging: Particle filtering half masks are packaged to protect them from contamination before use and with cardboard boxes to prevent mechanical damage. The packaging design and the product is considered to withstand the foreseeable conditions of use based on the visual inspection results given in the test report.</p>			
Article 7.5	<p>Material: Materials used in particle filtering half masks, according to the simulated wearing treatment and temperature conditioning results; It is understood it withstands handling and wear over the period for which the particle filtering half mask is designed to be used, it suffered mechanical failure of the facepiece or straps, any material from the filter media is released by the air flow through the filter has not constitute a hazard or nuisance for the wearer. The manufacturer declares that the materials used in manufacturing of the mask does not have an adverse affect to the health and safety of users.</p> <p>Based on the test result, the masks did not collapse when subject to simulated wearing and temperature conditioning. No nuisance situation is reported during the practical performance tests by human subjects.</p>			
Article 7.6	<p>Cleaning and disinfection: Particle filtering half mask is not designed to be as re-usable. No cleaning or disinfection procedure provided by the manufacturer.</p>			
Article 7.7	<p>Practical Performance:</p> <p>The test report indicates that the human subjects did not face any difficulty in performing the exercises while they were wear by the sample masks, in walking test or work simulation tests. The wearers did not report any failure by means of head harness / straps/ ear loops comfort. security of fastenings and field of vision. Also, no imperfections reported during total inward tests about the comfort. field of vision and fastening issues.</p>			
	Assessed Elements	Positive	Negative	Requirements in accordance with EN 149:2001 + A1:2009 and Result
	2. Head harness comfort	2	0	Positive results are obtained from the test subjects
	3. Security of fastenings	2	0	No imperfections
	5. Field of vision	2	0	
<p>Conditioning: (A.R.) As Received, original</p>				

Article 7.8	Finish of Parts: Particle filtering half masks, which are likely to come into contact with the user do not have sharp edges and do not contain burrs.																																								
Article 7.9.1	<p>Total Inward Leakage:</p> <p>The Total Inward Leakage test is conducted by 10 individual in an aerosol chamber with a walking band, and samples are taken during the conduction of the exercises defined in the standard. The samples used in the test are subjected to the conditioning required in the standard as temperature conditioning, and as received. The face dimensions of the subjects are also reported. The measurement details for each subject and for each exercise are available in tire test report.</p> <p>It was reported that:</p> <p>All 50 exercise measurement results are smaller or equal to 11% the values varies between 7,23% and 7,98%.</p> <p>All 10 individual's arithmetic mean is smaller or equal to 8% the values varies between 7,58% and 7,72%.</p> <p>According to the reported results, the product meets the limits for FFP2 classification.</p>																																								
Article 7.9.2.	<p>Penetration of filter material: Sodium Chloride Testing</p> <table border="1"> <thead> <tr> <th>Condition</th> <th>No. of Sample</th> <th>Sodium Chloride Testing 95L/min max (%)</th> <th>Requirements in accordance with EN 149: 2001 +A1:2009</th> <th>Results</th> </tr> </thead> <tbody> <tr> <td>(A.R.)</td> <td>36</td> <td>0,86</td> <td rowspan="3">FFP1 ≤ 20%</td> <td rowspan="9">Filtering half masks fulfill the requirements of the standard EN 149:2001 + A1:2009 given in 7.9.2 in range of the FFP1 and FFP2 classes.</td> </tr> <tr> <td>(A.R.)</td> <td>37</td> <td>1,05</td> </tr> <tr> <td>(A.R.)</td> <td>38</td> <td>0,95</td> </tr> <tr> <td>(S.W.)</td> <td>1</td> <td>0,99</td> <td rowspan="2">FFP2 ≤ 6%</td> </tr> <tr> <td>(S.W.)</td> <td>2</td> <td>1,01</td> </tr> <tr> <td>(S.W.)</td> <td>3</td> <td>1,03</td> <td rowspan="4">FFP3 ≤ 1%</td> </tr> <tr> <td>(M.S.T.C.)</td> <td>10</td> <td>0,98</td> </tr> <tr> <td>(M.S.T.C.)</td> <td>11</td> <td>0,96</td> </tr> <tr> <td>(M.S.T.C.)</td> <td>12</td> <td>0,90</td> </tr> </tbody> </table>					Condition	No. of Sample	Sodium Chloride Testing 95L/min max (%)	Requirements in accordance with EN 149: 2001 +A1:2009	Results	(A.R.)	36	0,86	FFP1 ≤ 20%	Filtering half masks fulfill the requirements of the standard EN 149:2001 + A1:2009 given in 7.9.2 in range of the FFP1 and FFP2 classes.	(A.R.)	37	1,05	(A.R.)	38	0,95	(S.W.)	1	0,99	FFP2 ≤ 6%	(S.W.)	2	1,01	(S.W.)	3	1,03	FFP3 ≤ 1%	(M.S.T.C.)	10	0,98	(M.S.T.C.)	11	0,96	(M.S.T.C.)	12	0,90
Condition	No. of Sample	Sodium Chloride Testing 95L/min max (%)	Requirements in accordance with EN 149: 2001 +A1:2009	Results																																					
(A.R.)	36	0,86	FFP1 ≤ 20%	Filtering half masks fulfill the requirements of the standard EN 149:2001 + A1:2009 given in 7.9.2 in range of the FFP1 and FFP2 classes.																																					
(A.R.)	37	1,05																																							
(A.R.)	38	0,95																																							
(S.W.)	1	0,99	FFP2 ≤ 6%																																						
(S.W.)	2	1,01																																							
(S.W.)	3	1,03	FFP3 ≤ 1%																																						
(M.S.T.C.)	10	0,98																																							
(M.S.T.C.)	11	0,96																																							
(M.S.T.C.)	12	0,90																																							

Conditioning: (M.S) Mechanical Strength
(T.C.) Temperature conditioning
(A.R.) As received, original
(S.W.) Simulated wearing treatment



Article 7.9.2	<p>Penetration of filter material: Paraffin Oil testing</p> <table border="1"> <thead> <tr> <th>Condition</th> <th>No. of Sample</th> <th>Paraffin oil Testing 95L/min max (%)</th> <th>Requirements in accordance with EN 149: 2001 +A1:2009</th> <th>Results</th> </tr> </thead> <tbody> <tr> <td>(A.R.)</td> <td>39</td> <td>1,88</td> <td rowspan="3">FFP1 ≤ 20%</td> <td rowspan="9">Filtering half masks fulfill the requirements of the standard EN 149:2001 + A1:2009 given in 7.9.2 in range of the FFP1 and FFP2 classes.</td> </tr> <tr> <td>(A.R.)</td> <td>40</td> <td>2,03</td> </tr> <tr> <td>(A.R.)</td> <td>41</td> <td>1,93</td> </tr> <tr> <td>(S.W.)</td> <td>4</td> <td>1,95</td> <td rowspan="2">FFP2 ≤ 6%</td> </tr> <tr> <td>(S.W.)</td> <td>5</td> <td>1,99</td> </tr> <tr> <td>(S.W.)</td> <td>6</td> <td>1,96</td> <td rowspan="4">FFP3 ≤ 1%</td> </tr> <tr> <td>(M.S.T.C.)</td> <td>13</td> <td>1,97</td> </tr> <tr> <td>(M.S.T.C.)</td> <td>14</td> <td>2,01</td> </tr> <tr> <td>(M.S.T.C.)</td> <td>15</td> <td>1,99</td> </tr> </tbody> </table> <p>Conditioning: (M.S) Mechanical Strength (T.C.) Temperature conditioning (A.R.) As received, original (S.W.) Simulated wearing treatment</p>					Condition	No. of Sample	Paraffin oil Testing 95L/min max (%)	Requirements in accordance with EN 149: 2001 +A1:2009	Results	(A.R.)	39	1,88	FFP1 ≤ 20%	Filtering half masks fulfill the requirements of the standard EN 149:2001 + A1:2009 given in 7.9.2 in range of the FFP1 and FFP2 classes.	(A.R.)	40	2,03	(A.R.)	41	1,93	(S.W.)	4	1,95	FFP2 ≤ 6%	(S.W.)	5	1,99	(S.W.)	6	1,96	FFP3 ≤ 1%	(M.S.T.C.)	13	1,97	(M.S.T.C.)	14	2,01	(M.S.T.C.)	15	1,99
Condition	No. of Sample	Paraffin oil Testing 95L/min max (%)	Requirements in accordance with EN 149: 2001 +A1:2009	Results																																					
(A.R.)	39	1,88	FFP1 ≤ 20%	Filtering half masks fulfill the requirements of the standard EN 149:2001 + A1:2009 given in 7.9.2 in range of the FFP1 and FFP2 classes.																																					
(A.R.)	40	2,03																																							
(A.R.)	41	1,93																																							
(S.W.)	4	1,95	FFP2 ≤ 6%																																						
(S.W.)	5	1,99																																							
(S.W.)	6	1,96	FFP3 ≤ 1%																																						
(M.S.T.C.)	13	1,97																																							
(M.S.T.C.)	14	2,01																																							
(M.S.T.C.)	15	1,99																																							
Article 7.10	Compatibility with skin: In Practical Performance report, the likelihood of mask materials in contact with the skin causing irritation or other adverse effect on health was not reported.																																								
Article 7.11	<p>Flammability</p> <table border="1"> <thead> <tr> <th>Condition</th> <th>No. of Sample</th> <th>Visual inspection</th> <th>Requirements in accordance with EN 149: 2001 +A1:2009</th> <th>Result</th> </tr> </thead> <tbody> <tr> <td>(A.R.)</td> <td>45</td> <td>Burn for 0,0s</td> <td rowspan="4">Filtering half mask shall not burn or not continue to burn for more than 5 s after removal from the flame</td> <td rowspan="4">Passed Filtering half masks fulfill requirements of the standard</td> </tr> <tr> <td>(A.R.)</td> <td>46</td> <td>Burn for 0,0s</td> </tr> <tr> <td>(T.C.)</td> <td>21</td> <td>Burn for 0,0s</td> </tr> <tr> <td>(T.C.)</td> <td>22</td> <td>Burn for 0,1s</td> </tr> </tbody> </table> <p>Conditioning: (A.R.) As received, original (T.C.) Temperature conditioning</p>					Condition	No. of Sample	Visual inspection	Requirements in accordance with EN 149: 2001 +A1:2009	Result	(A.R.)	45	Burn for 0,0s	Filtering half mask shall not burn or not continue to burn for more than 5 s after removal from the flame	Passed Filtering half masks fulfill requirements of the standard	(A.R.)	46	Burn for 0,0s	(T.C.)	21	Burn for 0,0s	(T.C.)	22	Burn for 0,1s																	
Condition	No. of Sample	Visual inspection	Requirements in accordance with EN 149: 2001 +A1:2009	Result																																					
(A.R.)	45	Burn for 0,0s	Filtering half mask shall not burn or not continue to burn for more than 5 s after removal from the flame	Passed Filtering half masks fulfill requirements of the standard																																					
(A.R.)	46	Burn for 0,0s																																							
(T.C.)	21	Burn for 0,0s																																							
(T.C.)	22	Burn for 0,1s																																							
Article 7.12	<p>Carbon dioxide content of the inhalation air:</p> <table border="1"> <thead> <tr> <th>Condition</th> <th>No. of sample</th> <th>CO2 content of the inhalation air (%) by volume</th> <th>An average CO2 content of the inhalation air</th> <th>Requirements in accordance with EN 149: 2001 +A1:2009</th> <th>Result</th> </tr> </thead> <tbody> <tr> <td>(A.R.)</td> <td>26</td> <td>0,45</td> <td rowspan="3">0,48 (%)</td> <td rowspan="3">CO2 content of the inhalation air shall not exceed an average of 1,0% by volume</td> <td rowspan="3">Passed Filtering half masks fulfill requirements of the standard</td> </tr> <tr> <td>(A.R.)</td> <td>27</td> <td>0,52</td> </tr> <tr> <td>(A.R.)</td> <td>28</td> <td>0,47</td> </tr> </tbody> </table> <p>Conditioning: (A.R.) As received, original</p>					Condition	No. of sample	CO2 content of the inhalation air (%) by volume	An average CO2 content of the inhalation air	Requirements in accordance with EN 149: 2001 +A1:2009	Result	(A.R.)	26	0,45	0,48 (%)	CO2 content of the inhalation air shall not exceed an average of 1,0% by volume	Passed Filtering half masks fulfill requirements of the standard	(A.R.)	27	0,52	(A.R.)	28	0,47																		
Condition	No. of sample	CO2 content of the inhalation air (%) by volume	An average CO2 content of the inhalation air	Requirements in accordance with EN 149: 2001 +A1:2009	Result																																				
(A.R.)	26	0,45	0,48 (%)	CO2 content of the inhalation air shall not exceed an average of 1,0% by volume	Passed Filtering half masks fulfill requirements of the standard																																				
(A.R.)	27	0,52																																							
(A.R.)	28	0,47																																							

<p>Article 7.13</p>	<p>Head harness: In Practical Performance and TIL test reports no adverse effects have been reported for donning and remove of the mask also the results of these tests indicates that the ear loops / head harness are capable of holding the mask firmly enough.</p>
<p>Article 7.14</p>	<p>Field of vision: In Practical Performance report, no adverse effects were reported for the field of vision availability when the mask is worn.</p>
<p>Article 7.15</p>	<p>Exhalation Valve(s): The model under inspection have no valves. Passed.</p>
<p>Article 7.16</p>	<p>Breathing Resistance: inhalation The overall evaluation in the figures gathered for 9 different samples 3 as received. 3 with temperature conditioning and 3 simulated wearing treatment conditioned complies with the limits given in the standard for FFP1, FFP2 and PFP3 classes. This is valid for inhalation results for 30 L/min, 95 L/min and exhalation at 160 L/min. Passed.</p>



Article 7.17	Clogging: This test is not applied to Particle Filtering Half Mask which is not reusable. (For single shift use devices, the clogging test is optional test. For re-usable devices test is mandatory.)
Article 7.18	Demountable Parts: There are no demountable parts on the product.
Article 8	Testing: All tests conducted according to Clause 8 of this standard is available in the test report and are evaluated in this report for qualification and classification of the mask.
Article 9	Marking – Packaging: Necessary markings are available on the product package (box). The name and trademark of the manufacturer is clearly visible. The type of the mask and the classification including the status of re-usability, the reference to EN 149:2001 +A1:2009 standard, the year of end of shelf life, using and storage instructions and pictograms and CE mark are available on the product package. The above evaluation is based on the technical document for packaging and marking, for box design. Verified Section 9.1 on the technical file. The technical documentation for mask design (drawing) also evaluated for marking requirements, drawing PSH-NRFM001. The mask marking indicates that the mask will carry information about the brandname (Pasha Home) of the manufacturer, type of mask, the reference to EN 149+A1:2009 standard and classification including the re-usability of the mask. The manufacturer also printed CE mark with our Notified Body number. The mask do not have sub-assemblies. The tested samples by the laboratory carry necessary marking information as stated in the technical documentation. the manufacturer shall also follow marking instruction in the technical file for serial production. Model PSH-NRFM001 drawing exists in the technical file Section 6 of the manufacturer.
Article 10	Information to be supplied by the manufacturer: In each of the smallest commercially available packaging of the product, implementation (installation instructions) pre-use controls, warning and usage limitations, storage and meanings of symbols / pictograms are defined. User instruction document in the technical file Section 8 found to be appropriate. The manufacturer shaft include this documented user information text in every smallest commercially available package.

PREPARED BY	APPROVED BY
PPE Expert 	Director 

ANHUI HONREN GROUP CO LTD
Xingyuan East Road, Economic Development Zone, Anhui, China

TEST REPORT

Report Date:13.12.2020

Report Number: 12-2020-T0575

CLIENT AND SAMPLE INFORMATION

TEST OWNER	PASHA HOME ITH. IHR, LTD. STI		
ADDRESS	Mahmutbey Mah. Istoc 1 Ada No: 154-156 Bagcilar / Istanbul TURKEY		
SAMPLE DESCRIPTION	Folding type protective mask		
BRAND NAME - MODEL	PASHA HOME / PSH-NRFM001		
TESTING STANDARD	EN 149:2001+A1:2009		
CASE NUMBER	CE-PPE-3749		
SAMPLE RECEIVE DATE	23.11.2020	TESTING START DATE	23.11.2020
DISINFECTION INSTRUCTION if applicable	Not given, single use only		
NUMBER OF SAMPLES	50	SAMPLE IDs:	1-46
AS RECEIVED SAMPLE NO	26-46		
CONDITIONING SAMLE NO	Simulated wearing treatment	1-2-3-4-5-6-7-8-9 (As received)	
	Temperature conditioning	10-11-12-13-14-15 (sample after test of mechanical strength)	
		16-17-18-19-20-21-22-23-24-25 (as received)	
Mechanical strength	10-11-12-13-14-15 (as received)		

The results given in this test report belongs to the samples tested. The report content cannot be recreated partially without the written consent of ANHUI HONREN GROUP CO LTD

**UNIVERSAL**
SERTİFİKASYON
VE GÖZETİM HİZM.
LTD. STI.
Necip Fazıl Bulvarı, Keleş Sitesi, E2 Blok, No:44/B4
Yukarı Dudullu-Ümraniye/İSTANBUL
Telefon: 0216 455 80 80 Faks: 0216 455 80 08
Sarıgazi V.D. 892 025 8722

Suat KAÇMAZ
Director

1. REPORT SUMMARY

TEST STANDARD	TESTNAME	RESULT	EVALUATION
EN 149:2001 + AI:2009 clause 8.5 EN 13274-1:2001	Total Inward Leakage Testing	Pass	FFP2
EN 149:2001 + AI:2009 clause 8.11 EN 13274-7:2019	Penetration of Filter Material	Pass	FFP2
EN 149:2001 + AI:2009 clause 8.6 EN 13274-4:2001	Flammability Testing	Pass	See results
EN 149:2001 + AI:2009 clause 8.7 EN 13274-6:2001	Carbon Dioxide Content of The Inhalation Air Testing	Pas	See results
EN 149:2001 + AI:2009 clause 8.9 EN 13274-3:2001	Breathing Inhalation Resistance-30 l/min	Pass	See results
	Breathing Inhalation Resistance-95 l/min	Pass	See results
EN 149:2001 + AI:2009 clause 8.9 EN 13274-3:2001	Exhalation Resistance, flow rate 160 l/min	Pass	See results

 UNIVERSAL
SERTİFİKASYON
VE GÖZETİM HİZİMLİ
TİC. LTD. STİ.
Etiler, Beşiktaş, İstanbul, E2 Blok, no. 11/78
Yukarı Dudullu-Ümraniye/İST. 4*1BİJL
Telefon: 0216 455 90 80 Faks: 0216 455 30 06
Sarıcazi V.D. 892 025 9722

2. TEST RESULTS AND EVALUATION

7.4 PACKAGING (EN 149:2001 + A1:2009 clause 8.2)

Test Method: Clause 8.2-Visual inspection

<u>REQUIREMENTS</u>	<u>RESULTS</u>	<u>COMMENT</u>
Particle filtering half masks shall be offered for sale packaged in such a way that they are protected against mechanical damage and contamination before use.	Pass	The masks were packed in sealed plastic bags, in larger plastic bags inside a large cardboard box that gave some protection against mechanical damage or contamination before use.

Lab A

7.5 MATERIAL (EN 149:2041 + A1:2009 clause 8.2, 8.3.1, 8.3.2)

Test Method: Clause 8.2-Visual inspection

Clause 8.3.1-Simulated wearing treatment

A breathing machine is adjusted to 25 cycles/min and 2,0 l/stroke. The particle filtering half mask was mounted on a Sheffield dummy head.

For testing, a saturator is incorporated in the exhalation line between the breathing machine and the dummy head, the saturator being set at a temperature in excess of 37 °C to allow for the cooling of the air before it reaches the mouth of the dummy head.

The air has been saturated at (37 + 2) °C at the mouth of the dummy head

Clause 8.3.2-Temperature conditioning

The ambient temperature for testing has been between 16 °C and 32 °C and the temperature limits has been subject to an accuracy of +1 °C.

a) for 24 h to a dry atmosphere of (70 + 3) °C;

b) for 24 h to a temperature of (-30 + 3) °C; and allow to return to room temperature for at least 4 h between exposures and prior to subsequent testing. The conditioning has been carried out in a manner which ensures that no thermal shock occurs.

REQUIREMENT	RESULTS	COMMENT
Material used shall be suitable to withstand handling and wear over the period for which the particle filtering half mask is designed to be used.	Pass	The material used were able to withstand handling and wear during the limited laboratory testing carried out.
Any material from the filter media released by the air flow through the filter shall not constitute a hazard or nuisance for the wearer.	Pass	It was not constitute a hazard or nuisance for the wearer.
After undergoing the conditioning described in 8.3.1. none of the particle filtering half masks shall have suffered mechanical failure of the facepiece or straps.	Pass	None of the specimens conditioned suffered mechanical failure.
When conditioned in accordance with 8.3.1. and 8.3.2. the particle filtering half mask shall not collapse.	Pass	None of the specimens had not collapse after conditioning.

Lab B

7.6. CLEANING AND DISINFECTING (EN 149:2001 + AI:2009 clause 8.4, 8.5, 8.11)

<u>REQUIREMENT</u>	<u>RESULTS</u>	<u>COMMENT</u>
If the particle filtering half mask is designed to be re-usable, the materials used shall withstand the cleaning and disinfecting agents and procedures to be specified by the manufacturer. With reference to 7.9.2. after cleaning and disinfecting the re-usable particle filtering half mask shall satisfy the penetration requirement of the relevant class.	N/A	This article is not applicable for tested protective mask which is single use disposable mask.

Test Method: Described in Clause 8.4, 8.5 and 8.11

7.7. PRACTICAL PERFORMANCE (EN 149:2001 + AI:2009 clause 8.4)

Test Method: Described in Clause 8.4

<u>REQUIREMENT</u>	<u>RESULTS</u>	<u>COMMENT</u>
The particle filtering half mask shall undergo practical performance tests under realistic conditions. These general tests serve the purpose of checking the equipment for imperfections that can not be determined by the tests described elsewhere in this standard. Two as received mask samples are used by two subject for the walking (10 mins walking with a speed of 6km/h) and work simulation (bended walking, crawling and basket filling exercises) tests.	No imperfections	Detail refer to Annex I

Annex I-Test Result:

Assessed elements	Positive Assessment	Negative Assessment	Requirements in accordance with EN 149:2001+A1 :2009	Assessment of Test Result Conformity / Nonconformity
The face piece fitting Head harness comfort Security of fastenings Field of vision	2 2 2 2	0 0 0 0	Filtering half masks should not have imperfections related to wearer's acceptance	Filtering half masks fulfil requirements of the standard EN 149:2001 + AI:2009 given in 7.7 No imperfections

Number of sample: 29 (A.R), 30 (A.R)

The subjects (MEG and MA) were able to complete the exercises and did not report any nuisance or problem with the mask.

7.8. FINISH OF PARTS (EN 149:2001 + AI:2009 clause 8.2)

Test Method: Described in Clause 8.2

<u>REQUIREMENT</u>	<u>RESULTS</u>	<u>COMMENT</u>
Parts of the device likely to come into contact with the wearer shall have no sharp edges or burrs.	Pass	None of the specimens used in laboratory testing showed evidence of sharp edges or burrs while visual inspection and performance tests.

7.9.1 TOTAL INWARD LEAKAGE (EN 149:2001 + A1:2009 clause 8.5)

Test Method: Described in Clause 8.5

REQUIREMENT	RESULTS	COMMENT
The total inward leakage consists of three components: face seal leakage, exhalation value leakage (if exhalation value fitted) and filter penetration. For particle filtering half masks fitted in accordance with the manufacturer's information, at least 46 out of the 50 individual results shall be not greater than: 25 % for FFP1, 11 % for FFP2, 5 % for FFP3 and in addition at least 8 out of the 10 individual wearer arithmetic means for the total inward leakage shall not be greater than: 22 % for FFP1, 8 % for FFP2, 2 % for FFP3	Pass	Classified as FFP2 Detail refer to Annex II


Annex II-Test Result:

The test results obtained are given in the tables as follows

Test Subject	No of sample	Cond.	1. Walk (%)	Head side/ side (%)	Head up/down (%)	Talk (%)	2. Walk (%)	Average (%)
1	31	A.R.	7,23	7,41	7,62	7,77	7,89	7,58
2	32	A.R.	7,31	7,52	7,69	7,79	7,96	7,65
3	33	A.R.	7,33	7,54	7,72	7,85	7,94	7,67
4	34	A.R.	7,35	7,55	7,71	7,82	7,93	7,67
5	35	A.R.	7,29	7,53	7,75	7,86	7,91	7,66
6	16	T.C.	7,34	7,60	7,71	7,84	7,95	7,68
7	17	T.C.	7,33	7,57	7,69	7,81	7,97	7,67
8	18	T.C.	7,31	7,60	7,72	7,83	7,95	7,68
9	19	T.C.	7,38	7,62	7,75	7,89	7,98	7,72
10	20	T.C.	7,34	7,63	7,72	7,85	7,92	7,69
All 50 individual exercise results were not greater than 11 % All 10 individual wearer arithmetic means were not greater than 8 %.								Pass (FFP2)

Test Subject	Face Length (mm)	Face Width (mm)	Face Depth (mm)	Mouth Width (mm)
1	117	155	130	60
2	113	148	128	62
3	112	160	134	59
4	115	148	125	61
5	120	158	132	57
6	118	150	134	59
7	115	152	130	57
8	117	155	134	59
9	114	149	128	57
10	110	150	131	55

For Information Only


UNIVERSAL
SERTİFİKASYON
VE GÖZETİM HİZMETLERİ
LTD. STİ.
 Etiler Bahçe Köyü Sit. E2 Blok, h10:4z/8a
 Beşiktaş / Beşiktaş / İSTANBUL
 Telefon: 0216 455 80 80 Faks: 0216 455 00 08
 Sıra No: V.D. 892 025 8722

7.9.2 PENETRATION OF FILTER MATERIAL (EN 149:2001 + A1:2009 clause 8.11)

Test Method: Described in Clause 8.11

REQUIREMENT			RESULTS	COMMENT
Classification	Max penetration of test aerosol		Pass	Detail refer to Annex IIIA and IIIB
	NaCl test 95 l/min % max	Paraffin oil test 95 l/min % max		
FFP1	20	20		
FFP2	6	6		
FFP3	1	1		

Annex IIIA – Test Result:

The test results obtained are given in the tables as follows:

No. of sample	Condition	Penetration of Sodium Chloride in accordance with EU 13274-7:2019 (%) Flow rate 95 l/min	Requirements in accordance with EN 149:2001 + A1:2009	Assessment of Test Result Conformity / Nonconformity
36	As received	0,86	FFP1 ≤ 20%	Passed Filtering half masks fulfill the requirements of the standard EN 149:2001+A1:2009 given in 7.9.2. in range of the first and second protection class (FFP1,FFP2)
37		1,05		
38		0,95		
1	Simulated wearing treatment	0,99	FFP2 ≤ 6%	
2		1,01		
3		1,03		
10	Mechanical strength + Temperature conditioned	0,98	FFP3 ≤ 1%	
11		0,96		
12		0,90		

Annex HIB-Test Result:

The test results obtained are given in the tables as follows:

No. of Sample	Condition	Penetration of Paraffin Oil Mist in accordance with EN 13274-7:2019 [%] Flow rate 95 l/min	Requirements in accordance with EN 149:2001+A1:2009	Assessment of Test Result Conformity / Nonconformity
39	As received	1,88	FFP1 ≤ 20 % FFP2 ≤ 6 % FFP3 ≤ 1 %	Passed filtering half masks fulfil the requirements of the standard EN 149:2001 +A1 :2009 given in 7.9.2 in range of the first and second protection classes (FFP1, FFP2)
40		2,03		
41		1,93		
4	Simulated wearing treatment	1,95		
5		1,99		
6		1,96		
13	Mechanical strength + Temperature conditioned	1,97		
14		2,01		
15		1,99		

7.10 COMPATIBILITY WITH SKIN (EN 149:2001 + A1:2009 clause 8.4, 8.5)

Test Method: Described in Clause 8.4 and 8.5.

REQUIREMENT	RESULTS	COMMENT
Materials that may come into contact with the wearer's skin shall not be known to be likely to cause irritation or any other adverse effect to health.	Pass	No irritation or any other adverse effect to health or sensitivity reported by the subjects during the practical performance and TIL tests.

7.11 FLAMMABILITY (EN 149:2001 + A1:2009 clause 8.6)

Test Method: Described in Clause 8.6

REQUIREMENT		RESULTS	COMMENT	
The material used shall not present a danger to the wearer and shall not be of highly flammable nature. When tested, the particle filtering half mask shall not burn or not to continue to burn 5s after removal from the flame.		Pass	Detail refer to Annex IV	
Annex IV - Test Result: The test results obtained are given in the tables as follows-				
No. of Sample	Condition	Visual inspection	Requirements in accordance with EN 149:2001+A1:2009	Assessment of Test Result Conformity / Nonconformity
45	As received	0,0 s	Filtering half mask shall not burn or not continue to burn for more than 5 s after removal from the flame	Passed Filtering half masks fulfill requirements of the standard EN 149:2001 + A I :2009 given in 7.1 I
46		0,0 s		
21	Temperature conditioned	0.0 s		
22		0.1 s		

7.12 CARBON DIOXIDE CONTENT OF THE INHALATION AIR (EN 149:2001 + A1:2009 clause 8.7)

Test Method: Described in Clause 8.7

REQUIREMENT	RESULTS	COMMENT
The carbon dioxide content of the inhalation air (dead space) shall not exceed an average of 1.0 % (by volume)	Pass	Detail refer to Annex V

Annex V-Test Result: The test results obtained are given in the tables as follows:

No. of Sample	Condition	CO2 content of the inhalation air (%) by volume	An average CO2 content of the inhalation air (%) by volume	Requirements in accordance with EN 149:2001+A1:2009	Assessment of Test Result Conformity / Nonconformity
26	As received	0,45	0,48	CO2 content of the inhalation air shall not exceed an average of 1,0% by volume	Passed Filtering half masks fulfill requirements of the standard EN 149:2001 +A1:2009 given in 7.12
27		0,52			
28		0,47			

7.13 HEAD HARNESS (EN 149:2001 + A1:2009 clause 8.4, 8.5)

Test Method: Described in Clause 8.4, 8.5

REQUIREMENT	RESULTS	COMMENT
The head harness shall be designed so that the particle filtering half-mask can be donned and removed easily.	Pass	No problem with the head harness reported by the wearers during the practical performance test.
The head harness shall be adjustable or self-adjusting and shall be sufficiently robust to hold the particle filtering half mask firmly in position and capable of maintaining total inward leakage requirements for the device.	Pass	No problem with the head harness reported by the wearers during the practical performance test.

7.14 FIELD OF VISION (EN 149:2001 + A1:2009 clause 8.4)

Test Method: Described in Clause 8.4

REQUIREMENT	RESULTS	COMMENT
The field of vision is acceptable if determined so in practical performance tests.	PASS	There were no adverse comments following practical performance tests.

7.15 EXHALATION VALVE (EN 149:2001 + A1:2009 clause 8.2, 8.3.4, 8.8, 8.9.1)

Test Method: Clause 8.2. 8.3.4. 8.8. 8.9.1

REQUIREMENT	RESULTS	COMMENT
A particle filtering half mask may have one or more exhalation valve(s). which shall function correctly in all orientations.	N/A	No exhalation valve in tested samples.
If an exhalation valve is provided it shall be protected against or be resistant to dirt and mechanical damage and may be shrouded or may include any other device that may be necessary for the particle filtering half mask to comply with 7.9	N/A	No exhalation valve in tested samples.
Exhalation valve(s), if fitted shall continue to operate correctly after a continuous exhalation flow of 300 l/min over a period of 30s.	N/A	No exhalation valve in tested samples.
When the exhalation valve housing is attached to the face blank. it shall withstand axially a tensile force of 10N applied for 10s.	N/A	No exhalation valve in tested samples.

7.16 BREATHING RESISTANCE (EN 149:2001 + A1:2009 clause 8.9)

Test Method: Described in Clause 8.9

REQUIREMENT				RESULTS	COMMENT
Classification	Max permitted resistance (mbar)			Pass	Detail refer to Annex VIA-VIB
	Inhalation		Exhalation		
30 l/min	95 l/min	160 l/min			
FFP1	0,6	2,1	3,0		
FFP2	0,7	2,4	3,0		
FFP3	1,0	3,0	3,0		

Annex VIA-Test Result:

The test results obtained are given in the tables as follows:

No. of Sample	Condition	Inhalation Resistance mbar)						Assessment of Test Result Conformity / Nonconformity	
		Flow rate 30 l/min [mbar]	Requirements in accordance with EN 149:2001+A1:2009		Flow rate 95 l/min [mbar]	Requirements in accordance with EN 149:2001+A1:2009			
42	As received	0.50	FFP1 ≤ 0.60		1.34	FFP1 ≤ 2.10		Passed Qualifies FFP1, FFP2, FFP3	
43		0.53			1.37				
44		0.49			1.37				
7	Simulated wearing treatment	0.52	FFP2 ≤ 0.70		1.40	FFP2 ≤ 2.40			
8		0.50			1.39				
9		0.51			1.41				
23	Temperature conditioned	0.49	FFP3 ≤ 1.0		1.36	FFP3 ≤ 3.00			
24		0.50			1.38				
25		0.49			1.37				
Exhalation Resistance									
No. of Sample	Condition	Flow rate	Facing directly	Facing vertically upwards	Facing vertically downwards	Lying on the left side	Lying on the right side	Requirements in accordance with EN 149:2001+A1:2009	Assessment of Test Result Conformity / Nonconformity
42	As received	l 60l/min	1,65	1,69	1,71	1,72	1,74	FFP1 ≤ 3.0	Passed Qualifies FFP1, FFP2, FFP3
43			1,71	1,71	1,72	1,75	1,78		
44			1,69	1,67	1,70	1,71	1,72		
7	Simulated wearing treatment		1,63	1,68	1,69	1,70	1,75	FFP2 ≤ 3.0	
8			1,68	1,70	1,73	1,74	1,78		
9			1,65	1,72	1,76	1,71	1,73		
23	Temperature conditioned		1.60	1,64	1,68	1,70	1,72	FFP3 ≤ 3.0	
24			1,58	1,65	1,63	1,69	1,73		
25			1,56	1,62	1,65	1,64	1,68		

7.17 CLOGGING (EN 149:2001 + A1:2009 c1a use 8.9, 8.10)

Test Method: Described in Clause 8.8, 8.10

REQUIREMENT	RESULTS	COMMENT
Valved particle filtering half masks: After clogging the inhalation resistances shall not exceed: FFP1:4mbar, FFP2:5mbar, FFP3:7mbar at 95L/min continuous flow. The exhalation resistance shall not exceed 3mbar at l60L/min continuous flow. Valueless particle filtering half masks: After clogging the inhalation resistances shall not exceed: FFP1:3mbar, FFP2:4mbar, FFP3:5mbar at 95L/min continuous flow	NAs	This is optional test and not desired by client.

7.18 DEMOUNTABLE PARTS (EN 149:2001 + A1:2009 clause 8.2)

Test Method: Described in Clause 8.2

REQUIREMENT	RESULTS	COMMENT
All demountable parts (if fitted) shall be readily connected and secured, where possible by hand	N/A	No demountable part.

Pass	Requirement satisfied.
NCR	Requirement not satisfied. Refer to the "Result details" section for more information.
NAs	Assessment not carried out.
N/A	Requirement not applicable.

Sample Photo



- End of Report -

NB 2163

ES TIPO TYRIMO SERTIFIKATAS

Sertifikato Nr.: 2163-PPE-1795

Kvėpavimo organų apsaugos priemonės, filtruojančios puskaukės, apsaugančios nuo dalelių, pagamintų iš

PASHA HOME ITH. IHR. LTD. ŠTĪ.

tikrinami ir vertinami pagal

**EN 149:2001 + A1:2009 Kvėpavimo organų apsaugos priemonės.
Filtruojamosios puskaukės, apsaugančios nuo dalelių.**

Remiantis tipo tyrimu, atliktu įvertinus bandymų ataskaitas, techninę bylą pagal Asmeninių apsaugos priemonių reglamento (ES) 2016/425 5 priedą, patvirtinama, kad gaminys atitinka reglamento reikalavimus.

Produkto apibrėžtis

Vienkartinė dalelių filtravimo puskaukė, skirta apsaugoti nuo kietųjų ir skystųjų aerozolių, yra sulankstoma, 5 sluoksnių, be vožtuvo, ausų dirželių ir reguliuojamo nosies strypo.

Prekės ženklo pavadinimas: Pasha Home

Modelis: PSH-NRFM001

Klasifikacija: FFP2 NR

Šiuo atveju gamintojui leidžiama naudoti notifikuotosios įstaigos numerį (2163) ir ant pirmiau nurodytų III kategorijos gaminių modelių galima pritvirtinti CE ženklą, kaip parodyta toliau, su;

-Pateikti atitinkamą ES atitikties deklaraciją pagal **asmeninės apsaugos** reikalavimus

Įrangos reglamento (ES) 2016/425 9 priedas.

-nuolatinis sėkmingas asmeninių apsaugos **priemonių reglamento (ES) 2016/425** ir darnųjų standartų reikalavimų laikymasis, užtikrintas atlikus vertinimą pagal reglamento **7 priedą (C2 modulis) arba 8 priedą (D modulis)** ne vėliau kaip per vienerius metus nuo serijinės gamybos pradžios.

Šis sertifikatas iš pradžių išduodamas **2020 m. gruodžio 16 d.** ir galioja penkerius metus, jei nepasikeičia atitinkamas darnusis standartas, turintis įtakos esminiams sveikatos ir saugos reikalavimams.



Direktorius

TECHNINIO ĮVERTINIMO ATASKAITA

ATASKAITOS DATA / NR.: 2020 12 15 / 2163-KKD-1795

Gamintojas: GAMINTOJAS: PASHA HOME SU. IHR. LTD. ŞTİ.

Adresas: Mahmutbey Mah. Istoc 1. Ada Nr.: 154-156 Bagcilar / Istanbul TURKIJA

Įvadas

Ši ataskaita skirta pirmiau nurodytam gamintojui, parengta pagal bandymų rezultatus, gautus iš ANHUI HONREN GROUP CO LTD, 2020 12 13, serijos kodas 12-2020-T0575, remiantis EN 149: 2001 + A1 : 2009. standartą ir gamintojo pateiktą 2020 m. spalio 25 d. techninę bylą (00 redakcija).

Gamintojo techninė byla, rizikos vertinimas pagal esminius sveikatos saugos reikalavimus ir bandymų ataskaita, įvertinta, ar jie atitinka Asmens apsaugos priemonių reglamento esminius reikalavimus, ir nustatyta, kad jie yra tinkami.

Ši ataskaita yra gamintojui išduoto ES tipo tyrimo sertifikato priedas ir neatskiriama jo dalis. Bandymų rezultatai ir išduotas sertifikatas priklauso tik išbandytam modeliui. Techninę ataskaitą iš viso sudaro 6 puslapiai.

Produkto aprašymas: Vienkartinė puskaukė, filtruojanti daleles, skirta apsaugai nuo kietų ir skystų aerozolių, yra sulankstoma, 5 sluoksnų, be vožtuvo, ausų dirželių ir reguliuojamo nosies strypo.

Komponentas ir medžiagos:

Komponentas	Materija I	Klasė
Išorinis sluoksnis	Spunbond audinys	50 g/m ²
I filtro sluoksnis	Karšto oro medvilninis audinys	60 g/m
II filtro sluoksnis	Išlydytas audinys	25 g/m
Vidinis sluoksnis	Spunbond audinys	30 g/m
Ausies dirželis	Spandeksas + nailonas	Plotis 5+/- 1 mm Ilgis: 200+20 mm
Nosies tiltelis	Polipropilenas + cinkuota geležinė viela	Plotis 5+/-1 mm Skersmuo: 0,5 +/-0,02 mm

Klasifikacija: FFP2 NR

Prekės ženklo pavadinimas: Pasha Home **Modelis:** PSH-NRFM001



ESSENTIALUS SVEIKATA ir SAUGA
EUROPOS SĄJUNGOS REGLAMENTE EU 2016/425 NUSTATYTI REIKALAVIMAI, SUSIJĘ SU PRODUKTUI
KYLANČIA RIZIKA

1.1. Projektavimo principai

1.1.1. Ergonomika

Apsauginės priemonės turi būti suprojektuotos ir pagamintos taip, kad numatytais naudojimo sąlygomis, kurioms jos yra skirtos, naudotojas galėtų įprastai atlikti su rizika susijusią veiklą, naudodamasis atitinkama aukščiausio įmanomo lygio apsauga.

1.1.2. Apsaugos lygiai ir klasės

1.1.2.1. Aukščiausias įmanomas apsaugos lygis

Optimalus apsaugos lygis, į kurį reikia atsižvelgti projektuojant, yra toks, kurį viršijus dėl apribojimų, atsirandančių dėl asmeninės apsaugos priemonės, jų nebūtų galima veiksmingai naudoti rizikos poveikio laikotarpiu arba įprastai vykdamas veiklą.

1.1.2.2. Apsaugos klasės, atitinkančios skirtingus rizikos lygius

Jei skirtingos numatomos naudojimo sąlygos yra tokios, kad galima išskirti kelis tos pačios rizikos lygius, projektuojant asmenines apsaugos priemones reikia atsižvelgti į atitinkamas apsaugos klases.

1.2. PPE nekalumas

1.2.1. Rizikos ir kitų būdingų nepatogių veiksmų nebuvimas

Asmeninės apsaugos priemonės turi būti suprojektuotos ir pagamintos taip, kad numatytais naudojimo sąlygomis būtų išvengta rizikos ir kitų nepatogių veiksmų.

1211. Tinkamos sudedamosios medžiagos

Medžiagos, iš kurių pagamintos asmeninės apsaugos priemonės, įskaitant bet kokius galimus jų skilimo produktus, neturi daryti neigiamo poveikio naudotojų sveikatai ar saugai.

1212. Patenkinama visų su naudotoju besiliečiančių asmeninių apsaugos priemonių dalių paviršiaus būklė

Visos asmeninių apsaugos priemonių dalys, kurios liečiasi arba gali liestis su naudotoju, kai dėvimos asmeninės apsaugos priemonės, turi būti be šiurkščių paviršių, aštrių briaunų, aštrių briaunų, aštrių smaigalių ir panašių dalykų, kurie gali sukelti pernelyg didelį dirginimą arba sužeidimus.

1213. Didžiausia leistina naudotojo kliūtis

Turi būti kuo mažiau trukdoma atlikti judesius, užimti pozą ir suvokti jutimus; be to, AAP neturi kelti pavojaus naudotojui ar kitiems asmenims.

1.3. Komfortas ir veiksmingumas

1.3.1. Asmeninių apsaugos priemonių pritaikymas prie naudotojo morfologijos

Asmeninės apsaugos priemonės turi būti suprojektuotos ir pagamintos taip, kad jas būtų galima teisingai uždėti ant naudotojo ir kad jos išliktų savo vietoje numatomą naudojimo laikotarpį, atsižvelgiant į aplinkos veiksmus, atliekamus veiksmus ir laikyseną. Šiuo tikslu turi būti įmanoma pritaikyti asmenines apsaugos priemones prie naudotojo morfologijos visomis tinkamomis priemonėmis, pavyzdžiui, tinkamomis reguliavimo ir tvirtinimo sistemomis arba tinkamu dydžių asortimentu.

1.3.2. Lengvumas ir konstrukcijos tvirtumas

Asmeninės apsaugos priemonės turi būti kuo lengvesnės, kad nenukentėtų konstrukcijos tvirtumas ir efektyvumas.

Be konkrečių papildomų reikalavimų, kuriuos jos turi atitikti, kad užtikrintų tinkamą apsaugą nuo atitinkamos rizikos (žr. 3 punktą), asmeninės apsaugos priemonės turi būti atsparios aplinkos reiškiniai, būdingų numatomoms naudojimo sąlygoms, poveikiui.

1.4. Gamintojo pateikta informacija

Pastabose, kurias turi parengti ir pateikti, kai asmeninės apsaugos priemonės pateikiamos rinkai, turi būti pateikta visa svarbi informacija apie:

- a) Be Bendrijoje įsisteigusio gamintojo ir (arba) jo įgaliotojo atstovo pavadinimo ir adreso
 - b) Saugojimas, naudojimas, valymas, priežiūra, aptarnavimas ir dezinfekavimas. valymas. priežiūra ar dezinfekavimo apsauga, rekomenduojama gamintojų, neturi daryti neigiamo poveikio asmeninėms apsauginėms priemonėms ar naudotojams, kai jos naudojamos pagal atitinkamas instrukcijas:
 - c) Veikimas, užfiksuotas atliekant techninius bandymus, kuriais tikrinami atitinkamų asmeninių apsaugos priemonių apsaugos lygiai arba klasės;
 - d) Tinkami asmeninių apsaugos priemonių priedai ir tinkamų atsarginių dalių charakteristikos;
 - e) Skirtingiems rizikos lygiams tinkamos apsaugos klasės ir atitinkamos naudojimo ribos;
 - f) Asmeninių gamybos priemonių arba tam tikrų jų sudedamųjų dalių pasenimo terminas arba pasenimo laikotarpis;
 - g) Transportavimui tinkamos pakuotės tipas;
 - h) Bet kokių ženklų reikšmė (žr. 2.12 punktą)
 - i) Kai tinkama, pagal 5 straipsnio 6 dalies b punktą taikomos direktyvų nuorodos;
 - j) Notifikuotosios įstaigos, dalyvavusios asmeninių apsaugos priemonių projektavimo etape, pavadinimas, adresas ir identifikacinis numeris
- Šios pastabos, kurios turi būti tikslios ir suprantamos, turi būti pateiktos bent jau paskirties valstybės narės valstybine (-ėmis) kalba (-omis).



2. PAPILDOMI REIKALAVIMAI, BŪDINGI KELIOMS PPE KLASĖMS AR TIPAMS

2.1. AAP su reguliavimo sistemomis

Jei asmeninėse apsaugos priemonėse yra reguliavimo sistemos, jos turi būti suprojektuotos ir pagamintos taip, kad jas sureguliuvus, numatomomis naudojimo sąlygomis jos netyčia neatsijungtų.

2.3. Apsauginės veido, akių ir kvėpavimo takų apsaugos priemonės

Bet koks naudotojo veido, akių, regėjimo lauko ar kvėpavimo sistemos apribojimas dėl asmeninių apsaugos priemonių turi būti kuo mažesnis. Šių tipų asmeninių apsaugos priemonių ekranai turi būti tokio optinio neutralumo laipsnio, kuris atitiktų naudotojo veiklos tikslumo laipsnį ir trukmę.

Jei reikia, tokios asmeninės apsaugos priemonės turi būti apdorotos arba aprūpintos priemonėmis, neleidžiančiomis rūkti.

Naudotojams, kuriems reikalinga regėjimo korekcija, skirtų asmeninių apsaugos priemonių modeliai turi būti suderinami su akiniais ar kontaktinių lęšių dėvėjimu.

2.4. Senstančios asmeninės apsaugos priemonės

Jei žinoma, kad senėjimas gali turėti didelės įtakos naujų asmeninių apsaugos priemonių konstrukciniams veiksams, ant kiekvienos rinkai pateiktos asmeninės apsaugos priemonės ir ant jos pakuotės turi būti neištrinamai ir nedviprasmiškai pažymėtas pagaminimo mėnuo ir metai ir (arba), jei įmanoma, pasenimo mėnuo ir metai.

Jei gamintojas negali išpareigoti dėl asmeninių apsaugos priemonių naudingo tarnavimo laiko, jo instrukcijose turi būti pateikta visa informacija, reikalinga tam, kad pirkėjas ar naudotojas galėtų nustatyti pagrįstą pasenimo mėnesį ir metus, atsižvelgdamas į modelio kokybės lygį ir veiksmingas laikymo, naudojimo, valymo, aptarnavimo ir priežiūros sąlygas.

Jei tikėtina, kad dėl senėjimo, atsirandančio periodiškai naudojant gamintojo rekomenduojamą valymo procesą, pastebimai ir greitai blogėja asmeninių apsaugos priemonių eksploatacinės savybės, pastarasis, jei įmanoma, privalo kiekvieną rinkai pateiktą asmeninių apsaugos priemonių vienetą pažymėti ženklu, kuriame būtų nurodytas didžiausias valymo operacijų skaičius, kurį galima atlikti prieš tai, kai įrangą reikia patikrinti arba išmesti. Jei tokio ženklo nėra, gamintojas turi pateikti šią informaciją savo instrukcijose.

2.6. Asmeninės apsaugos priemonės, skirtos naudoti potencialiai sprogoje aplinkoje

Asmeninės apsaugos priemonės, skirtos naudoti potencialiai sprogoje aplinkoje, turi būti suprojektuotos ir pagamintos taip, kad jos negalėtų tapti elektros, elektrostatinio ar smūgio sukkelto lanko ar kibirkšties šaltiniu, galinčiu sukelti sprogstamojo mišinio užsidegimą.

2.8. Asmeninės apsaugos priemonės, skirtos intervencijai labai pavojingose situacijose

Instrukcijose, kurias gamintojas pateikia kartu su asmeninėmis apsaugos priemonėmis, skirtomis darbu labai pavojingose situacijose, visų pirma turi būti pateikti duomenys, skirti kompetentingiems, apmokytiems asmenims, kurie yra kvalifikuoti jas aiškinti ir užtikrinti, kad naudotojas jas taikytų.

Instrukcijose taip pat turi būti aprašyta procedūra, kurios reikia laikytis norint patikrinti, ar asmeninės apsaugos priemonės yra tinkamai sureguliuotos ir ar jos veikia, kai jas dėvi naudotojas. Jei asmeninėse apsaugos priemonėse yra signalizacija, kuri įsijungia, kai nėra įprastai užtikrinamo apsaugos lygio, signalizacija turi būti suprojektuota ir įrengta taip, kad naudotojas galėtų ją pastebėti numatomomis naudojimo sąlygomis.

2.9. Asmeninės apsaugos priemonės su komponentais, kuriuos naudotojas gali reguliuoti arba nuimti

Jei asmeninėse apsaugos priemonėse yra sudedamųjų dalių, kurias naudotojas gali pritvirtinti, sureguliuoti ar nuimti, kad jas

pakeistų, tokios sudedamosios dalys turi būti suprojektuotos ir pagamintos taip, kad jas būtų galima lengvai pritvirtinti, sureguliuoti ir nuimti be įrankių.

2.12. Asmeninės apsaugos priemonės, pažymėtos vienu ar daugiau identifikavimo ar atpažinimo ženklų, tiesiogiai ar netiesiogiai susijusių su sveikata ir sauga

Identifikavimo arba atpažinimo ženklai, tiesiogiai ar netiesiogiai susiję su sveikata ir sauga, tvirtinami prie šių tipų ar klasių, pageidautina, kad jie būtų suderintų piktogramų arba ideogramų pavidalo ir išliktų puikiai įskaitomi visą numatomą asmeninių apsaugos priemonių naudojimo laiką. Be to, šie ženklai turi būti išsamūs, tikslūs ir suprantami, kad būtų išvengta bet kokio klaidingo aiškinimo: visų pirma, jei tokiuose ženkluose yra žodžių ar sakinių, jie turi būti pateikti valstybės narės, kurioje įranga bus naudojama, valstybine (-ėmis) kalba (-omis).

Jei AAP (arba AAP sudedamoji dalis) yra per maža, kad ant jos būtų galima pritvirtinti dalį būtino ženklinimo, atitinkama informacija turi būti nurodyta ant pakuotės ir gamintojo pastabose.

3. PAPILDOMI REIKALAVIMAI, BŪDINGI KONKREČIAI RIZIKAI.

3.10.1. Kvėpavimo takų apsauga

Kvėpavimo sistemos apsaugai skirtos asmeninės apsaugos priemonės turi sudaryti galimybę tiekti naudotojui kvėpuoti tinkamą orą, kai jis patenka į užterštą ir (arba) nepakankamos deguonies koncentracijos atmosferą.


Kvėpuoti tinkamas oras, tiekiamas naudotojui per asmenines apsaugos priemones, turi būti gaunamas tinkamomis priemonėmis, pavyzdžiui, filtruojant užterštą orą per asmenines apsaugos priemones arba tiekiant jį iš išorinio neužteršto šaltinio.

Šių tipų asmeninių apsaugos priemonių sudedamosios medžiagos ir kitos sudedamosios dalys turi būti parinktos arba suprojektuotos ir įmontuotos taip, kad užtikrintų tinkamą naudotojo kvėpavimą ir kvėpavimo higieną atitinkamu dėvėjimo laikotarpiu numatomomis naudojimo sąlygomis.

Veido gaubto sandarumas ir slėgio kritimas įkvepiant, o filtravimo įtaisų atveju - valymo pajėgumas turi užtikrinti, kad teršalų skverbimasis iš užterštos atmosferos būtų pakankamai mažas ir nekenktų naudotojo sveikatai ar higienai.

Ant asmeninių apsaugos priemonių turi būti išsamiai nurodytos konkrečios įrangos savybės, kurios kartu su instrukcijomis leistų apmokytam ir kvalifikuotam naudotojui teisingai naudoti asmenines apsaugos priemones.

Filtravimo įrangos atveju gamintojo instrukcijose taip pat turi būti nurodyta, kiek laiko turi būti laikoma nauja filtravimo įranga. originali pakuotė.



Techninis EN 149:2001 + A1:2009 standarto ir kitų standartų, į kuriuos jame daroma nuoroda, punktai, atitinkantys (ES) 2016/425 direktyvą

Atitinka EN 149:2001 + A1:2009 standarto reikalavimus				
5 straipsnis	<p>Klasifikacija: Dalelių filtravimo puskaukė</p> <p>Vertinama kaukė, remiantis bandymų rezultatais ir gamintojo pateikta technine byla, klasifikuojama kaip: Filtravimo efektyvumas ir didžiausias bendras vidinis nuotėkis - klasifikuojama kaip FFP2</p> <p>Kaukė klasifikuojama kaip skirta naudoti vieną pamainą NR</p>			
7.4 straipsnis	<p>Pakuotė: Daleles filtruojančios puskaukės pakuojamos taip, kad prieš naudojimą būtų apsaugotos nuo užteršimo ir kartoninėse dėžutėse, kad būtų išvengta mechaninių pažeidimų. Laikoma, kad pakuotės dizainas ir gaminys yra atsparūs numatomomis naudojimo sąlygomis, remiantis bandymų ataskaitoje pateiktais vizualinės patikros rezultatais.</p>			
7.5 straipsnis	<p>Medžiaga: Medžiagos, naudojamos dalelių filtravimo puskaukėse, atsižvelgiant į imitacinio dėvėjimo ir temperatūros kondicionavimo rezultatus; suprantama, kad ji atlaiko tvarkymą ir dėvėjimą per laikotarpį, kuriam dalelių filtravimo puskaukė yra skirta naudoti, ji patyrė mechaninį veido okuliario ar dirželių gedimą, bet kokia medžiaga iš filtravimo terpės išsiskiria iš oro srauto per filtrą ir nekelia pavojaus ar nepatogumų dėvėtojui. Gamintojas pareiškia, kad kaukės gamybai naudotos medžiagos neturi neigiamo poveikio naudotojų sveikatai ir saugai.</p> <p>Remiantis bandymo rezultatais, imituojant dėvėjimą ir temperatūrinės sąlygas, kaukės nesugriuvo. Atliekant praktinio veikimo bandymus žmonės nepranešė apie jokią nepatogią situaciją.</p>			
Straipsnis 7.6	<p>Valymas ir dezinfekavimas: Kietųjų dalelių filtravimo puskaukė nėra skirta daugkartiniam naudojimui. Gamintojas nepateikė jokios valymo ar dezinfekavimo procedūros.</p>			
7.7 straipsnis	<p>Praktinis veikimas:</p> <p>Bandymų ataskaitoje nurodyta, kad žmonėms, kuriems buvo uždėtos bandomosios kaukės, atliekant ėjimo ar darbo imitavimo bandymus nebuvo jokių sunkumų atliekant pratimus. Nešiotojai nepranešė apie jokių galvos diržų / dirželių / ausų kilpų patogumo, užsegimo saugumo ir regėjimo lauko sutrikimus. Taip pat nebuvo trūkumai, apie kuriuos pranešta atliekant bendrus vidinius bandymus dėl patogumo, regėjimo lauko ir tvirtinimo problemų.</p>			
	Įvertinti elementai	Teigiamas	Neigiamas	Reikalavimai pagal EN 149:2001 + A1:2009 ir Result
	2. Galvos diržų patogumas	2	0	Teigiami rezultatai iš tiriamųjų Nėra trūkumų
	3. Tvirtinimo detalių saugumas	2	0	
	5. Regėjimo laukas	2	0	

	Sąlygos: (A.R.) Kaip gauta, originalus				
7.8 straips	Dalių apdaila: Daleles filtruojančios puskaukės, kurios gali liestis su naudotoju, neturi aštrių briaunų ir šerpetų.				
7.9.1 straips nis	<p>Bendras vidinis nuotėkis:</p> <p>Bendro vidinio nuotėkio bandymas atliekamas 10 asmenų aerozolio kameroje su vaikščiojimo juosta, o mėginiai imami atliekant standarte apibrėžtus pratimus. Bandymui naudojami mėginiai yra kondicionuojami standarte reikalaujamo būdu, t. y. temperatūriniu kondicionavimu, ir tokie, kokie buvo gauti. Taip pat nurodomi tiriamųjų veido matmenys. Kiekvieno tiriamojo ir kiekvieno pratimo matavimo duomenys pateikiami padangų bandymo ataskaitoje.</p> <p>Buvo pranešta, kad:</p> <p>Visų 50 pratimų matavimo rezultatai yra mažesni arba lygūs 11 %, vertės svyruoja nuo 7,23 % iki 7,98 %.</p> <p>Visų 10 asmenų aritmetinis vidurkis yra mažesnis arba lygus 8 %, vertės svyruoja nuo 7,58 % iki 7,72 %.</p> <p>Remiantis pateiktais rezultatais, produktas atitinka FFP2 klasifikacijos ribas.</p>				
Straipsnis 7.9.2.	Filtravimo medžiagos prasiskverbimas: Natrio chlorido bandymas				
	Būklė	Mėginio Nr.	Natrio chlorido tyrimas 95L/min max (%)	Reikalavimai pagal EN 149: 2001 +A1:2009	Rezultatai Filtravimo puskaukės atitinka standarto EN 149:2001 + A1:2009 reikalavimus nurodyta 7.9.2 skirsnyje FFP1 ir FFP2 klasių diapazone.
	(A.R.)	36	0,86	FFP1 20%	
	(A.R.)	37	1,05		
	(A.R.)	38	0,95		
	(S.W.)	1	0,99	FFP2 6%	
	(S.W.)	2	1,01		
	(S.W.)	3	1,03	FFP3 1%	
	(M.S.T.C.)	10	0,98		
	(M.S.T.C.)	11	0,96		
(M.S.T.C.)	12	0,90			

Kondicionavimas: (M.S) Mechaninis stiprumas
(T.C.) Temperatūros kondicionavimas
(A.R.) Kaip gauta, originalus
(S.W.) Imituotas dėvėjimo apdorojimas



7.9.2 straips nis	Filtravimo medžiagos prasiskverbimas: Parafininių degimų bandymas				
	Būklė	Mėginio Nr.	Parafininių degimų tyrimas 95L/min max (%)	Reikalavimai pagal EN 149: 2001 +A1:2009	Rezultatai Filtravimo puskaukės atitinka standarto EN 149:2001 + A1:2009 reikalavimus nurodyta 7.9.2 punkte, FFP1 ir FFP2 klasių diapazone.
	(A.R.)	39	1,88	FFP1 20%	
	(A.R.)	40	2,03		
	(A.R.)	41	1,93		
	(S.W.)	4	1,95	FFP2 6%	
	(S.W.)	5	1,99		
	(S.W.)	6	1,96	FFP3 1%	
	(M.S.T.C.)	13	1,97		
	(M.S.T.C.)	14	2,01		
(M.S.T.C.)	15	1,99			

Kondicionavimas: (M.S.) Mechaninis stiprumas (T.C.) Temperatūrinis kondicionavimas
(A.R.) Gautas originalus
(S.W.) Imituotas dėvėjimo apdorojimas

7.10 straips nis	Suderinamumas su oda: Ataskaitoje "Praktinis veikimas" nepranešta apie tikimybę, kad kaukės medžiagos, susidūrusios su oda, gali sukelti dirginimą ar kitokį neigiamą poveikį sveikatai.					
7.11 straips nis	Būklė	Mėginio Nr.	Vizuali apžiūra	Reikalavimai pagal EN 149: 2001 +A1:2009	Rezultatas Priimta Filtravimo puskaukės atitinka standarto reikalavimus	
	Degimas					
	(A.R.)	45	Degimas 0,0 s	Filtruojanti puskaukė neturi degti ar toliau degti ilgiau kaip 5 s po nuėmimo nuo liepsnos.		
	(A.R.)	46	Degimas 0,0 s			
	(T.C.)	21	Degimas 0,0 s			
(T.C.)	22	Degimas 0,1 s				

Sąlygos: (A.R.) Kaip gauta, originalus						
Būklė	(T.C.) Temperatūrinis kondicionavimas	Mėginio koeficientas	CO2 kiekis įkvepiamame ore (%)	Vidutinis CO2 kiekis įkvepiamame ore	Reikalavimai pagal EN 149: 2001 +A1:2009	Rezultatas
(A.R.)		o Nr.	pagal tūrį	0,48 (%)	CO2 kiekis įkvepiamas oras neviršija vidutiniškai 1,0 % tūrio	Priimta Filtravimas per pusę kaukės įvykdyti reikalavimai standartas
(A.R.)		26	0,45			
(A.R.)		27	0,52			
(A.R.)		28	0,47			

7.12 straipsnis	Anglies dioksido kiekis įkvepiamame ore: Sąlygos: (A.R.) Kaip gauta, originalus
7.13 straipsnis	Galvos diržai: Be to, šių bandymų rezultatai rodo, kad ausų kilpos ir galvos diržai pakankamai tvirtai laiko kaukę.
7.14 straipsnis	Matymo laukas: Ataskaitoje apie praktinį veikimą nepranešta apie neigiamą poveikį regėjimo lauko prieinamumui dėvint kaukę.
7.15 straipsnis	Iškvėpimo vožtuvas (-ai): Tikrinamame modelyje nėra vožtuvų. Priimta.
7.16 straipsnis	Kvėpavimo pasipriešinimas: įkvėpimas Bendras 9 skirtingų mėginių 3 gautų mėginių bendras įvertinimas. 3 su kondicionavimu pagal temperatūrą ir 3 imituojant dėvėjimą pagal kondicionavimą atitinka FFP1, FFP2 ir PFP3 klasių standarte nurodytas ribines vertes. Tai galioja įkvėpimo rezultatams, kai įkvepiama 30 L/min, 95 L/min ir iškvėpimo, kai įkvepiama 160 L/min. Priimta.



7.17 straipsnis	Užsikimšimas: Šis bandymas netaikomas dalelių filtravimo puskaukei, kuri nėra daugkartinio naudojimo. (Vienos pamainos prietaisams užsikimšimo bandymas yra neprivalomas. Daugkartinio naudojimo prietaisų bandymas yra privalomas.)
7.18 straipsnis	Išmontuojamos dalys: Išardomų dalių gaminyje nėra.
Straipsnis 8	Testavimas: Visi bandymai, atlikti pagal šio standarto 8 punktą, pateikiami bandymo ataskaitoje ir įvertinami šioje ataskaitoje, kad kaukė atitiktų kvalifikaciją ir būtų klasifikuojama.
9 straipsnis	Ženklimas - Pakuotė: Ant gaminio pakuotės (dėžės) yra reikalingi ženklai. Aiškiai matomas gamintojo pavadinimas ir prekės ženklas. Ant gaminio pakuotės turi būti nurodytas kaukės tipas ir klasifikacija, įskaitant pakartotinio naudojimo statusą, nuorodą į standartą EN 149:2001 +A1:2009, tinkamumo vartoti termino pabaigos metus, naudojimo ir laikymo instrukcijos, piktogramos ir CE ženklas. Pirmiau pateiktas vertinimas grindžiamas pakuotės ir ženklavimo techniniu dokumentu, skirtu dėžutės dizainui. Patikrinta techninio dokumento 9.1 skirsnis. Ženklavimo reikalavimams taip pat įvertinti kaukės konstrukcijos techniniai dokumentai (brėžinys), brėžinys PSH-NRFM001. Kaukės ženklavime nurodoma, kad ant kaukės bus pateikta informacija apie gamintojo prekės ženklą ("Pasha Home"), kaukės tipą, nuoroda į standartą EN 149+A1:2009 ir klasifikaciją, įskaitant galimybę kaukę naudoti pakartotinai. Gamintojas taip pat atspausdina CE ženklą su mūsų notifikuotosios įstaigos numeriu. Kaukė neturi mazgų. Laboratorijos išbandyti pavyzdžiai turi būtina ženklavimo informaciją, kaip nurodyta techniniuose dokumentuose. Gamintojas taip pat laikosi serijinei gamybai skirtoje techninėje byloje pateiktų ženklavimo nurodymų. Modelio PSH-NRFM001 brėžinys yra gamintojo techninės bylos 6 skyriuje.
10 straipsnis	Informaciją pateikia gamintojas: įspėjamieji ir naudojimo apribojimai, saugojimas ir simbolių / piktogramų reikšmės. Naudotojo instrukcijos dokumentas techninės bylos 8 skirsnyje pripažintas tinkamu. Gamintojas šachtą šį dokumentuotą naudotojo informacijos tekstą įtraukia į kiekvieną mažiausią prekyboje prieinamą pakuotę.

PREPARED BY	APPROVED BY
PPE Expert 	Director 

ANHUI HONREN GROUP CO LTD
Xingyuan East Road, ekonominės plėtros zona, Anhui, Kinija

TESTO ATASKAITA

Ataskaitos data: 13.12.2020

Ataskaitos numeris: 12-2020-T0575

INFORMACIJA APIE KLIENTĄ IR PAVYZDĮ

TESTO VALDYTOJAS	PASHA HOME ITH. IHR, LTD. STI		
ADRESAS	Mahmutbey Mah. Istoc 1 Ada No: 154-156 Bagcilar / Istanbul TURKIJA		
PAVYZDŽIO APRAŠYMAS	Sulankstomo tipo apsauginė kaukė		
PREKĖS ŽENKLAS - MODELIS	PASHA HOME / PSH-NRFM001		
BANDYMŲ STANDARTAS	EN 149:2001+A1:2009		
ATVEJO NUMERIS	CE-PPE-3749		
PAVYZDŽIO GAVIMO DATA	23.11.2020	TESTAVIMO PRADŽIOS DATA	23.11.2020
DIZINFEKCIJA INSTRUKCIJA, jei taikoma	Nesuteikta, tik vienkartiniam naudojimui		
MĖGINIŲ SKAIČIUS	50	Pavyzdžių ID:	1-46
KAIP GAUTAS MĖGINYS NR.	26-46		
KONDICIONAVIMAS NE	Imituojamas dėvėjimas gydymas	1-2-3-4-5-6-7-8-9 (kaip gauta)	
	Temperatūra kondicionavimas	10-11-12-13-14-15 (mėginys po mechaninio bandymo stiprybė)	
		16-17-18-19-20-21-22-23-24-25 (kaip gauta)	
	Mechaninis atsparumas	10-11-12-13-14-15 (kaip gauta)	

Šioje bandymų ataskaitoje pateikti rezultatai priklauso išbandytiems pavyzdžiams. Be raštiško ANHUI HONREN GROUP CO LTD sutikimo ataskaitos turinio negalima iš dalies atkurti.


UNIVERSAL
SERTİFİKASYON
VE GÖZETİM HİZM.
TİC. LTD. STI.
Necip Fazıl Bulvarı, Keleş Sitesi, E2 Blok, No:44/84
Yukarı Dudullu-Ümraniye/İSTANBUL
Telefon: 0216 455 80 80 Faks: 0216 455 80 08
Sarıgazi V.D. 892 025 8722
Suat KAÇMAZ
Director

1. ATASKAITOS SANTRAUKA

TESTAS STANDART AS	TESTNAME	REZULTAT AS	ĮVERTINIMAS
EN 149:2001 + AI:2009 8.5 punktas EN 13274-1 :2001	Bendras vidinio nuotėkio bandymas	Perduoti	FFP2
EN 149:2001 + AI :2009 8.11 punktas EN 13274-7:2019	Filtravimo medžiagos prasiskverbimas1	Perduoti	FFP2
EN 149:2001 + AI:2009 8.6 punktas EN 13274-4:2001	Degumo bandymas	Perduoti	Žiūrėti rezultatus
EN 149:2001 + AI:2009 8.7 punktas EN 13274-6:2001	Anglies dioksido kiekis įkvepiamame ore	Pas	Žiūrėti rezultatus
EN 149:2001 + AI:2009 8.9 punktas EN 13274-3:2001	Kvėpavimo pasipriešinimas įkvepiant - 30 l/min	Perduoti	Žiūrėti rezultatus
	Kvėpavimo pasipriešinimas įkvepiant-95 l/min	Perduoti	Žiūrėti rezultatus
EN 149:2001 + AI:2009 8.9 punktas EN 13274-3:2001	Iškvėpavimo pasipriešinimas, srautas 160 l/min	Perduoti	Žiūrėti rezultatus


UNIVERSAL
 SERTIFIKASYON
 VE GÖZETİM HİZİMLİ
 TIC. LTD. STI.
 Şişli Etiler Bulvarı, Keleş Sitesi E2 Blok, no. 44/78
 Yukarı Dudulu Ümraniye/İST.4*1BİLL
 Telefon: 0216 455 90 80 Faks: 0216 455 30 06
 Sarıcazi V.D. 892 025 9722

2. BANDYMŲ REZULTATAI IR VERTINIMAS

7.4 PAKUOTĖ (EN 149:2001 + A1:2009 8.2 punktas)

Bandymo metodas: punktas 8.2-Vizualinis patikrinimas

<u>REIKALAVIMAI</u>	<u>REZULTATAI</u>	<u>KOMENTARAS</u>
Dalelių filtravimo puskaukės turi būti siūloma parduoti plastikiniuose maišeliuose, supakuoti taip, kad jie yra apsaugoti nuo mechaninių pažeidimų ir naudojimą. užteršimo prieš naudojimą.	Kaukės buvo supakuotos į sandarias didesniuose plastikiniuose maišeliuose	didelėje kartoninėje dėžėje, kurią, tam tikros apsaugos nuo mechaninių pažeidimų užteršimo prieš naudojimą.

A laboratorija

7.5 MATERIALAS (EN 149:2041 + A1:2009 8.2, 8.3.1, 8.3.2 punktai)

Bandymo metodas: punktas 8.2-Vizualinis patikrinimas

8.3.1 punktas - imituota dėvėjimo procedūra

Kvėpavimo aparatas sureguliuotas taip, kad būtų 25 ciklai per minutę ir 2,0 l/stūmimas. Daleles filtruojanti puskaukė buvo pritvirtinta prie Šefildo manekeno galvos.

Atliekant bandymus, į iškvėpimo liniją tarp kvėpavimo aparato ir manekeno galvos įmontuojamas saturatorius, kurio temperatūra nustatoma aukštesnė nei 37 °C, kad oras atvėstų prieš jam patenkant į manekeno galvos burną.

Oras prie manekeno galvos burnos buvo prisotintas (37 + 2) °C temperatūros.

8.3.2 punktas-Temperatūrinis kondicionavimas

Bandymų metu aplinkos temperatūra buvo nuo 16 °C iki 32 °C, o temperatūros ribos priklausė nuo +1 °C tikslumu.

a) 24 val. sausoje (70 + 3) °C temperatūroje;

b) 24 val. į (-30 + 3) °C temperatūrą; tarp ekspozicijų ir prieš vėlesnius bandymus bent 4 val. palaikykite kambario temperatūroje. Kondicionavimas buvo atliktas taip, kad būtų išvengta šiluminio šoko.

REIKALAVIMAS	REZULTATAI	KOMENTARAS
Naudojama medžiaga turi būti tinkama, kad būtų atspari tvarkymui ir dėvėjimuisi per laikotarpį, kuriuo dalelių filtravimas pusė kaukės skirta naudoti.	Perduoti	Atliekant ribotus laboratorinius bandymus, naudotos medžiagos buvo atsparios tvarkymui ir dėvėjimuisi.
Bet kokia medžiaga iš filtravimo medžiagos, išsiskirianti dėl oro srauto per filtrą, neturi kelti pavojaus ar trukdo dėvėtojui.	Perduoti	Jis nekėlė pavojaus ar nepatogumų dėvėtojui.
Po 8.3.1 punkte aprašyto kondicionavimo nė viena daleles filtruojanti puskaukė neturi būti mechaniškai sugedusi.	Perduoti	Nė vienas iš kondicionuotų bandinių nepatyrė mechaninio gedimo.
Kai sąlygos atitinka 8.3.1. ir 8.3.2. dalelių filtravimo puskaukė neturi suirti.	Perduoti	Nė vienas bandinys po kondicionavimo nesugriuvo.

B laboratorija

7.6. VALYMAS IR DEZINFEKTAVIMAS (EN 149:2001 + AI:2009 8.4, 8.5, 8.11 punktai)

<u>REIKALAVIMA</u> <u>S</u>	<u>REZULTATAI</u>	<u>KOMENTARAS</u>
Jei daleles filtruojanti puskaukė yra skirta daugkartiniam naudojimui, naudojamos medžiagos turi būti atsparios gamintojo nurodytoms valymo ir dezinfekavimo priemonėms ir procedūroms. Pagal 7.9.2 punktą po valymo ir dezinfekavimo pakartotinai tinkama naudoti dalelių filtravimo puskaukė turi atitikti atitinkamos klasės skvarbos reikalavimą.	NETAIKOMA	Šis straipsnis netaikomas išbandytoms apsauginėms kaukėms, kurios yra vienkartinės vienkartinės kaukės.

Bandymo metodas: Aprašyta 8.4, 8.5 ir 8.11 punktuose.

7.7. PRAKTINIS NAUDOJIMAS (EN 149:2001 + AI:2009 8.4 punktas)

Bandymo metodas: Aprašyta 8.4 punkte

<u>REIKALAVIMA</u> <u>S</u>	<u>REZULTATAI</u>	<u>KOMENTARAS</u>
Su daleles filtruojančia puskauke atliekami praktinio veikimo bandymai realiomis sąlygomis. Šių bendrųjų bandymų tikslas - patikrinti, ar įranga neturi trūkumų, kurių negalima nustatyti atliekant kituose šio standarto punktuose aprašytus bandymus. Du gauti kaukės mėginiai naudojami dviem tiriamiesiems atliekant ėjimo (10 min. ėjimo 6 km/val. greičiu) ir darbo imitavimo (sulenкто ėjimo, šliaužimo ir krepšelio pildymo pratimų) testus.	Jokių trūkumų	Išsami informacija pateikta I priede

I priedas - bandymo rezultatai:

Įvertinti elementai	Teigiamas įvertinimas	Neigiamas vertinimas	Reikalavimai pagal EN 149:2001+A1:2009	Testo rezultatų įvertinimas Atitiktis / neatitiktis
Pritaikymas prie veido dalies Galvos diržų patogumas Užsegimų saugumas Regėjimo laukas	2 2 2 2	0 0 0 0	Filtravimo puskaukės neturėtų turėti trūkumų, susijusių su naudotojo priimtinumu	Pusės kaukės filtravimas atitinka standarto EN 149:2001 + AI:2009 reikalavimus. pateikta 7.7 punkte Jokių trūkumų

Įmties skaičius: 29 (A.R), 30 (A.R)

Tiriamieji (MEG ir MA) sugebėjo atlikti pratimus ir nepranešė, kad kaukė jiems keltų kokių nors nepatogumų ar problemų.

7.8. DALYKŲ APDAILA (EN 149:2001 + AI:2009 8.2 punktas)

Bandymo metodas: Aprašyta 8.2 punkte

<u>REIKALAVIMAS</u>	<u>REZULTATAI</u>	<u>KOMENTARAS</u>
Prietaiso dalys, kurios gali liestis su dėvėtoju, neturi turėti aštrių briaunų ar įbrėžimų.	Perduoti	Atliekant vizualinę apžiūrą ir eksploatacinius bandymus, nė viename iš bandinių, naudotų laboratoriniams bandymams, nebuvo aštrių briaunų ar įbrėžimų.

7.9.1 İŞ VİSİO İVİRŞİNİO NUOSTOLIO (EN 149:2001 + Aİ:2009 8.5 punkt)

Bandyo metodos: Aprašyta 8.5 punkte

REIKALAVIMAS	REZULTATAI	KOMENTARAS
Bendrą vidinį nuotėkį sudaro trys komponentai: priekinio sandariklio nuotėkis, iškvėpimo vertės nuotėkis (jei įrengta iškvėpimo vertė) ir prasiskverbimas pro filtrą. Kietųjų dalelių filtravimo puskaukės, įrengtos pagal gamintojo informaciją, ne mažiau kaip 46 iš 50 atskirų rezultatų turi būti ne didesni kaip: FFP1 - 25 %, FFP2 - 11 %, FFP3 - 5 %, be to, ne mažiau kaip 8 iš 10 atskirų naudotojų aritmetiniai vidurkiai bendram vidiniam nuotėkiui turi būti ne didesni kaip: FFP1 - 22 %, FFP2 - 8 %, FFP3 - 2 %.	Perduoti	Klasifikuojama kaip FFP2 Išsami informacija pateikta II priede

II priedas - bandymo rezultatai:

Gauti bandymų rezultatai pateikiami lentelėse

Testo objektas	Mėginio Nr.	Sąlyga.	1. Ėjimas (%)	Galvos pusė/šona s (%)	Galva aukšty n (%)	Kalbėjimas (%)	2. Ėjimas (%)	Vidutiniškai (%)
1	31	A.R.	7,23	7,41	7,62	7,77	7,89	7,58
2	32	A.R.	7,31	7,52	7,69	7,79	7,96	7,65
3	33	A.R.	7,33	7,54	7,72	7,85	7,94	7,67
4	34	A.R.	7,35	7,55	7,71	7,82	7,93	7,67
5	35	A.R.	7,29	7,53	7,75	7,86	7,91	7,66
6	16	T.C.	7,34	7,60	7,71	7,84	7,95	7,68
7	17	T.C.	7,33	7,57	7,69	7,81	7,97	7,67
8	18	T.C.	7,31	7,60	7,72	7,83	7,95	7,68
9	19	T.C.	7,38	7,62	7,75	7,89	7,98	7,72
10	20	T.C.	7,34	7,63	7,72	7,85	7,92	7,69
Visų 50 atskirų pratimų rezultatai buvo ne didesni kaip 11 %. Visų 10 atskirų nešiotųjų aritmetiniai vidurkiai buvo ne didesni kaip 8 %.								Patenkinama (FFP2)

Testo objektas	Veido ilgis (mm)	Veido plotis (mm)	Veido gylis (mm)	Burnos plotis (mm)
1	117	155	130	60
2	113	148	128	62
3	112	160	134	59
4	115	148	125	61
5	120	158	132	57
6	118	150	134	59
7	115	152	130	57
8	117	155	134	59
9	114	149	128	57
10	110	150	131	55

Tik informacijai

7.9.2 FILTRŲ MATERIALO PENETRACIJA (EN 149:2001 + A1:2009 8.11 punktas)

Bandymo metodas: Aprašyta 8.11 punkte

REIKALAVIMAS			REZULTATAI	KOMENTARAS
Klasifikacija	Didžiausia bandomojo aerozolio skvarba		Perduoti	Išsamiau žr. IIIA priedą ir IIIB
	NaCl bandymas 95 l/min proc.	Parafininės alyvos bandymas 95 l/min % maks.		
	FFP1	20		
	FFP2	6		
FFP3	1	1		

IIIA priedas - Bandymo rezultatai:

Gauti bandymų rezultatai pateikiami lentelėse:

Mėginio Nr.	Būklė	Natrio chlorido skverbtis pagal ES 13274-7:2019 (%) Srauto greitis 95 l/min	Reikalavimai pagal EN 149:2001 + A1:2009	Bandymo rezultatų atitiktis / neatitiktis įvertinimas
36	Kaip gauta	0,86	FFP1 20%	Priimta Filtravimo puskaukės atitinka standarto EN 149:2001+A1:2009 reikalavimus nurodyta 7.9.2 punkte, pirmosios ir antrosios apsaugos klasės diapazone (FFP1,FFP2)
37		1,05		
38		0,95		
1	Imituojamas dėvėjimo apdorojimas	0,99	FFP2 6%	
2		1,01	FFP3 1%	
3		1,03		
10	Mechaninis atsparumas + Temperatūra kondicionuojama	0,98		
11		0,96		
12		0,90		

Priedas HIB testo rezultatai:

Gauti bandymų rezultatai pateikiami lentelėse:

Nr. Pavyzdys	Būklė	Parafino aliejaus miglos skverbtis į pagal EN 13274-7:2019 [%] Srauto greitis 95 l/min	Reikalavimai pagal EN 149:2001+A1:2009	Testo rezultatų įvertinimas Atitiktis / neatitiktis
39	Kaip gauta	1,88	FFP1 20 % FFP2 6 % FFP3 1 %	Priimta filtruojančios puskaukės atitinka standarto EN 149:2001 +A1 :2009 pateikta 7.9.2 punkte nurodytos pirmosios ir antrosios apsaugos klasės (FFP1, FFP2)
40		2,03		
41		1,93		
4	Imituojamas dėvėjimas gydymas	1,95		
5		1,99		
6		1,96		
13	Mechaninis atsparumas + Temperatūra sąlyginis	1,97		
14		2,01		
15		1,99		

7.10 SUDERINAMUMAS SU ODA (EN 149:2001 + A1:2009 8.4, 8.5 punktai)

Bandymo metodas: Aprašyta 8.4 ir 8.5 punktuose.

REIKALAVIMAS	REZULTATAI	KOMENTARAS
Medžiagos, kurios gali liestis su naudotojo odai neturi būti žinoma, kad gali sukelti dirginimą ar kitokį neigiamą poveikį sveikatai.	Perduoti	Atliekant praktinio atlikimo ir TIL bandymus tiriamieji nepranešė apie jokią dirginimą ar kitokį neigiamą poveikį sveikatai ar jautrumui.

7.11 PELENKAMUMAS (EN 149:2001 + A1:2009 8.6 punktas)

Bandymo metodas: Aprašyta 8.6 punkte

REIKALAVIMAS		REZULTATAI	KOMENTARAS	
Naudojama medžiaga neturi kelti pavojaus dėvinčiajam ir neturi būti labai degi. Atliekant bandymą, daleles filtruojanti puskaukė turi nesiblaškyti arba nesiblaškyti 5 s po to, kai ji nuimama nuo liepsnos.		Perduoti	Išsami informacija pateikta IV priede	
IV priedas - Bandymo rezultatai: Bandymų rezultatai pateikiami lentelėse.				
Mėginio Nr.	Būklė	Vizuali apžiūra	Reikalavimai pagal EN 149:2001+A1:2009	Bandymo rezultatų atitiktis / neatitiktis įvertinimas
45	Kaip gauta	0,0 s	Pusės kaukės filtravimas turi nedegti ir nedegti ilgiau kaip 5 s po pašalinimo iš liepsnos	Priimta Filtravimo puskaukės atitinka standarto EN 149:2001 reikalavimus + A I :2009 pateikta 7.1 I
46		0,0 s		
21	Temperatūra kondicionuojama	0.0 s		
22		0.1 s		

7.12 Anglies dioksido kiekis įkvėpiamame ore (EN 149:2001 + A1:2009 8.7 punktas)

Bandymo metodas: Aprašyta 8.7 punkte

REIKALAVIMAS	REZULTATAI	KOMENTARAS
Anglies dioksido kiekis įkvėpiamame ore (negyvojoje erdvėje) neturi viršyti vidutiniškai 1,0 % (pagal tūrį)	Perduoti	Išsami informacija pateikta V priede

V priedas - bandymo rezultatai: Bandymų rezultatai pateikiami lentelėse:

Mėginio Nr.	Būklė	CO2 kiekis įkvėpiamame ore (%) pagal tūrį	Vidutinis CO2 kiekis įkvėpiamame ore (%) tūrio)	Reikalavimai pagal EN 149:2001+A1:2009	Bandymo rezultatų atitiktis / neatitiktis įvertinimas
26	Kaip gauta	0,45	0,48	CO2 kiekis įkvėpiamame ore neturi viršyti vidutiniškai 1,0 % tūrio	Priimta Filtravimo puskaukės atitinka standarto EN 149:2001 +A1:2009 reikalavimus. 7.12 skirsnyje
27		0,52			
28		0,47			

7.13 GALVUTĖS ĮSPĖJIMAS (EN 149:2001 + A I:2009 8.4, 8.5 punktai)

Bandymo metodas: Aprašyta 8.4, 8.5 punktuose

REIKALAVIMAS	REZULTATAI	KOMENTARAS
Galvos diržai turi būti suprojektuoti taip, kad daleles filtruojančią puskaukę galima lengvai užsidėti ir nuimti.	Perduoti	Praktinio veikimo bandymo metu naudotojai nepranešė apie jokiais problemas, susijusias su galvos diržais.
Galvos diržai turi būti reguliuojami arba savaime susireguliuojantys ir turi būti pakankamai tvirta, kad daleles filtruojanti puskaukė tvirtai laikytųsi savo vietoje ir galėtų išlaikyti visus prietaisui keliamus vidinio nuotėkio reikalavimus.	Perduoti	Praktinio veikimo bandymo metu naudotojai nepranešė apie jokiais problemas, susijusias su galvos diržais.

7.14 VIDINIO POKYČIO LAUKAS (EN 149:2001 + A1:2009 8.4 punktas)

Bandymo metodas: Aprašyta 8.4 punkte

REO_UIREMENT	REZULTATAI	KOMENTARAS
--------------	------------	------------

Regėjimo laukas yra priimtinas, jei nustatyta, kad taip ir praktiniuose našumo bandymuose.	PASS	Atlikus praktinio veikimo bandymus neigiamų pastabų negauta.
--	------	--

7.15 IŠDŪKIMO VENTILAS (EN 149:2001 + A1:2009 8.2, 8.3.4, 8.8, 8.9.1 punktai)

Bandymo metodas: 8.2 punktas. 8.3.4. 8.8. 8.9.1

REIKALAVIMAS	REZULTATAI	KOMENTARAS
Daleles filtruojanti puskaukė gali turėti vieną ar daugiau iškvėpimo vožtuvų, kurie turi tinkamai veikti visais kryptimis.	NETAIKOMA	Tirtuose mėginiuose nėra iškvėpimo vožtuvo.
Jei įrengtas iškvėpimo vožtuvas, jis turi būti apsaugotas nuo purvo ir mechaninių pažeidimų arba atsparios tokiems pažeidimams ir gali būti uždengtos arba turėti bet kokią kitą įtaisą, kurio gali prirėikti dalelių filtravimo puskaukė atitinka 7.9 punktą	NETAIKOMA	Tirtuose mėginiuose nėra iškvėpimo vožtuvo.
Iškvėpimo vožtuvas (-ai), jei jis (jie) įrengtas (-i), ir toliau turi būti teisingai veikia po nepertraukiamo 300 l/min iškvėpimo srauto per 30 s.	NETAIKOMA	Tirtuose mėginiuose nėra iškvėpimo vožtuvo.
Kai iškvėpimo vožtuvo korpusas pritvirtintas prie jis turi atlaikyti 10 s veikiančią 10 N tempimo jėgą.	NETAIKOMA	Tirtuose mėginiuose nėra iškvėpimo vožtuvo.

7.16 Kvėpavimo pasipriešinimas (EN 149:2001 + A1:2009 8.9 punktas)

Bandymo metodas: Aprašyta 8.9 punkte

ATKŪRIMAS				REZULTATAI	KOMENTARAS
				Perduoti	Išsami informacija pateikta VIA-VI B priede
Klasifikacija	Didžiausias leistinas pasipriešinimas (mbar)				
	Įkvėpus		Iškvėpimas		
	30 l/min	95 l/min	160 l/min		
FFP1	0,6	2,1	3,0		
FFP2	0,7	2,4	3,0		
FFP3	1,0	3,0	3,0		

VIA priedo VIA testo rezultatai:

Gauti bandymų rezultatai pateikiami lentelėse:

Mėginio Nr.	Būklė	Atsparumas įkvėpimui mbar)						Bandymų rezultatų atitiktis vertinimas /	
		Srauto greitis 30 l/min [mbar]	Reikalavimai pagal EN 149:2001+A1:2009			Srauto greitis 95 l/min [mbar]	Reikalavimai pagal EN 149:2001+A1:2009		
42	Kaip gauta	0.50	FFP1 0,60			1.34	FFP1 2,10 FFP2	Išlaikė kvalifikacinius reikalavimus	
43		0.53				1.37			
44		0.49				1.37			
7	Imituota dėvėti gydymas	0.52	FFP2 0,70			1.40	2,40		
8		0.50				1.39			
9		0.51				1.41			
23	Temperatūra sąlyginis	0.49	FFP3 1.0			1.36	FFP3 3.00		
24		0.50				1.38			
25		0.49				1.37			
Iškvėpimas		Pasipriešinimas							
Nr. Pavyzdys	Būklė	Srautas tarifas	Susiduria ant su tiesiogia	Susiduria ant su vertikaliai į viršų	Susiduria ant su vertikaliai žemyn	Melo apie kairioji	Melo apie dešinėje	Reikalavimai pagal EN 149:2001+A1:2009	Įvertinimas Bandymo rezultatas Neatitiktis
42	Kaip gauta	I 60l/min	1,65	1,69	1,71	1,72	1,74	FFP1 3.0	Išlaikytas atitinka FFP1, FFP2, FFP3 reikalavimus
43			1,71	1,71	1,72	1,75	1,78		
44			1,69	1,67	1,70	1,71	1,72		
7	Imituota dėvėti gydymas		1,63	1,68	1,69	1,70	1,75	FFP2 3.0	
8			1,68	1,70	1,73	1,74	1,78		
9			1,65	1,72	1,76	1,71	1,73		
23	Temperatūra sąlyginis		1,60	1,64	1,68	1,70	1,72	FFP3 3.0	
24			1,58	1,65	1,63	1,69	1,73		
25			1,56	1,62	1,65	1,64	1,68		

7.17 Uždengimas (EN 149:2001 + A1:2009 c1a naudojimas 8.9, 8.10)

Bandymo metodas: Aprašyta 8.8, 8.10 punktuose

REIKALAVIMAS	REZULTATAI	KOMENTARAS
<p>Puskaukės su vožtuvais, filtruojančios daleles: Po užsikimšimo įkvėpimo pasipriešinimas neturi viršyti: FFP1: 4mbar, FFP2: 5mbar, FFP3: 7mbar, kai nepertraukiamas 95 l/min srautas. Iškvėpimo pasipriešinimas neturi viršyti 3mbar, esant 160L/min nepertraukiamam srautui. Bevertės dalelių filtravimo puskaukės: Po užsikimšimo įkvėpimo pasipriešinimas neturi viršyti: FFP1:3mbar, FFP2: 4mbar, FFP3: 5mbar, kai nepertraukiamas 95 l/min srautas</p>	NAs	Tai neprivalomas testas, kurio klientas nepageidauja.

7.18 NEMOKAMOS DALYS (EN 149:2001 + A1:2009 8.2 punktas)

Bandymo metodas: Aprašyta 8.2 punkte

ATKŪRIMAS	REZULTATAI	KOMENTARAS

Visos nuimamos dalys (jei įrengtos) turi būti lengvai sujungiamos ir pritvirtinamos, jei įmanoma, rankomis.	NETAIKO MA	Nėra nuimamos dalies.
---	---------------	-----------------------

"PassRequirement" reikalavimas įvykdytas.

NCRReikalavimas neįvykdytas. Daugiau informacijos rasite skyriuje "Išsami informacija apie rezultatą".

NAĮvertinimas neatliktas.

N/ARReikalavimas netaikomas.

ampl nuotrauka



- Ataskaitos pabaiga -